

ADDENDUM NO. 4

**PROJECT: GRANBY JR SR HIGH SCHOOL STANDBY GENERATOR REMOVAL
AND**

REPLACEMENT

IFB/RFP Number: BD-26-1275-GRANB-GJSHS-125578

Issuing Authority: Town of Granby, MA, by Holly Young, Chief Procurement Officer.

Date: 4/13/2026

This Addendum forms part of the Contract Documents and modifies the original Bidding Documents as noted below. Bidders must acknowledge receipt of this Addendum No. 3 in the space provided on the Bid Form. Failure to do so may lead to the rejection of the bid as non-responsive.

Question 4: Please provide manufacturer and model number of panels to be protected by the new Surge protection devices. High school, East Meadow Elementary, and Pumphouse.


Response:

Jr. Sr. High School - Square D 89419

East Meadow - Eaton Pow-R-Line Switchboard 900P025h01 R14

Pump House - Easton EZ2036

East Meadow Main Panel


SWITCHBOARD SECTION
 LISTED
 2 OF 2
 No. D 03738088
Printed in U.S.A.



Pow-R-Line[®] Switchboard

Volts	480Y/277V	~	G. O. No.	SBS0802980	
Phase	3	Wire	4	Item No.	008
Frequency	60 Hz	Section No.		2 Of 2	
Mfd. At	Sumter SC	Date	8/31/2017		
Current Ratings - Amperes					
Supply	1200	Neut.	1200		
Section	1200	Neut.	1200		
Enclosure Type	1				

This Section Is Rated For Use On A Circuit Capable Of Delivering Not More Than 65 KA RMS Sym Amperes, 480 Volts maximum. When Protected By A Current Limiting Main Device, A --- Ampere Maximum Class --- Fuse Or A Type NGS Circuit Breaker Rated Not More Than --- Amperes Must Be Used.

The Short Circuit Rating Of This Switchboard Section Is Equal To The Lowest Rating Of (1) Any Section Electrically Connected In Series Or (2) Any Installed Panelboard Having A Marked Short Circuit Rating Or (3) Any Device Installed Except As Noted In The Series Rating Information Manual Attached Or (4) 42KA Max For Any Lineup Containing An RD/RDC Feeder Device Mounted On Distribution Chassis.

If This Section Contains A Control Transformer, The Secondary Voltage is 120V.

If This Section Contains A Bonded Neutral, The Bonding Means Shall Only Be Removed For Test Purposes.

900P025H01 R14

Assembled in USA

Pump House Panel (picture 1)



Pump House Panel (picture 2)



Jr. Sr. High 1st Floor West Panel



Jr. Sr. High 2nd Floor Laundry Panel



Jr. Sr. High 2nd Floor West Panel



Jr. Sr. High Boiler Room Panel



Jr. Sr. High Girls Locker Room Panel



Jr. Sr. High 1st Floor East Tower Panel

