

Lead in Water Test Results Summary: Echo School District #5

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

Legend:

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red** and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow** and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
concession stand west sink KF	22030100-001KF	10/24/2025	ND	Low	[enter date]	[enter result]	[autofill]
concession stand center sink KF	22030100-002KF	10/24/2025	ND	Low			
concession stand east sink KF	22030100-003KF	10/24/2025	ND	Low			
new wing girls bathroom left BF	22030100-004BF	10/24/2025	ND	Low			
new wing girls bathroom center BF	22030100-005BF	10/24/2025	ND	Low			
new wing girls bathroom right BF	22030100-006BF	10/24/2025	ND	Low			
new wing famly bathroom BF	22030100-007BF	10/24/2025	ND	Low			
new wing boys bathroom left BF	22030100-008BF	10/24/2025	ND	Low			
new wing boys bathroom center BF	22030100-009BF	10/24/2025	ND	Low			
new wing boys bathroom right BF	22030100-010BF	10/24/2025	ND	Low			
wood shop BF	22030100-011BF	10/24/2025	ND	Low			
FFA classroom 124 lab 1 CF	22030100-012CF	10/24/2025	ND	Low			
FFA classroom lab 2 CF	22030100-013CF	10/24/2025	ND	Low			
FFA classroom lab 3 CF	22030100-014CF	10/24/2025	ND	Low			
FFA Kitchen Faucet KF	22030100-015KF	10/24/2025	ND	Low			
old gym bathroom girls left BF	22030100-016BF	10/24/2025	ND	Low			
science room lab 1 CF	22030100-018CF	10/24/2025	ND	Low			
science room lab 2 CF	22030100-019CF	10/24/2025	ND	Low			
science room lab 3 CF	22030100-020CF	10/24/2025	ND	Low			
science room lab 4 CF	22030100-021CF	10/24/2025	ND	Low			
science room lab 5 CF	22030100-022CF	10/24/2025	ND	Low			
new gym water bottle filler west WB	22030100-023WB	10/24/2025	ND	Low			
new gym drinking fountain west DW	22030100-024DW	10/24/2025	ND	Low			
new gym drinking fountain east DW	22030100-025DW	10/24/2025	ND	Low			
maloy classroom 122 CF	22030100-026CF	10/24/2025	ND	Low			
maloy classroom 122 DW	22030100-027DW	10/24/2025	ND	Low			
robinson classroom 121 CF	22030100-028CF	10/24/2025	ND	Low			
robinson classroom 121 DW	22030100-029DW	10/24/2025	ND	Low			
thew classroom 120 CF	22030100-030CF	10/24/2025	ND	Low			
thew classroom 120 DW	22030100-031DW	10/24/2025	ND	Low			
campbell classroom 119 CF	22030100-032CF	10/24/2025	ND	Low			
campbell classroom 119 DW	22030100-033DW	10/24/2025	ND	Low			
girls locker room left BF	22030100-034BF	10/24/2025	1	Low			
girls locker room right BF	22030100-035BF	10/24/2025	ND	Low			
officials girls bathroom BF	22030100-036BF	10/24/2025	2.4	Low			
officials boy bathroom BF	22030100-037BF	10/24/2025	1.2	Low			
boys locker room left BF	22030100-038BF	10/24/2025	ND	Low			
boys locker room right BF	22030100-039BF	10/24/2025	ND	Low			
old gym drinking fountain right DW	22030100-040DW	10/24/2025	ND	Low			
old gym drinking fountain left DW	22030100-041DW	10/24/2025	ND	Low			
old gym bathroom girls right BF	22030100-042BF	10/24/2025	ND	Low			
old gym bathroom boys left BF	22030100-043BF	10/24/2025	ND	Low			
old gym bathroom boys right BF	22030100-044BF	10/24/2025	ND	Low			
cafeteria right KF	22030100-045KF	10/24/2025	7.8	Low			
cafeteria center KF	22030100-046KF	10/24/2025	ND	Low			
cafeteria left KF	22030100-047KF	10/24/2025	ND	Low			
cafeteria hand wash KF	22030100-048KF	10/24/2025	ND	Low			

commons drinking fountain left DW	22030100-049DW	10/24/2025	ND	Low			
commons drinking fountain right DW	22030100-050DW	10/24/2025	ND	Low			
special needs 104 CF	22030100-051CF	10/24/2025	ND	Low			
special needs 104 bathroom BF	22030100-052BF	10/24/2025	ND	Low			
staff bathroom 106 BF	22030100-053BF	10/24/2025	ND	Low			
grade school 108 CF	22030100-054CF	10/24/2025	1.4	Low			
grade school girls bathroom BF	22030100-055BF	10/24/2025	2.1	Low			
grade school boys bathroom BF	22030100-056BF	10/24/2025	1.7	Low			
grade school 110 CF	22030100-057CF	10/24/2025	ND	Low			
preschool 112 CF	22030100-058CF	10/24/2025	ND	Low			
preschool 113 CF	22030100-059CF	10/24/2025	ND	Low			
grade school 111 CF	22030100-060CF	10/24/2025	ND	Low			
grade school 111 DW	22030100-061DW	10/24/2025	ND	Low			
grade school 109 CF	22030100-062CF	10/24/2025	ND	Low			
grade school 109 DW	22030100-063DW	10/24/2025	ND	Low			
grade school 107 CF	22030100-064CF	10/24/2025	1.6	Low			
3rd floor drinking fountain DW	22030100-065DW	10/24/2025	1.1	Low			
grade school drinking fountain DW	22030100-066DW	10/24/2025	ND	Low			
district office girls bathroom BF	22030100-067BF	10/24/2025	ND	Low			
district office boys bathroom BF	22030100-068BF	10/24/2025	4.7	Low			
district office staff bathroom BF	22030100-069BF	10/24/2025	1	Low			
district office old sick room NS	22030100-070NS	10/24/2025	ND	Low			
district office staff lounge KF	22030100-071KF	10/24/2025	1.1	Low			
district office drinking fountain DW	22030100-072DW	10/24/2025	ND	Low			
3rd floor life skills 206 right CF	22030100-073CF	10/24/2025	2.7	Low			
3rd floor life skills 206 center CF	22030100-074CF	10/24/2025	5.2	Low			
3rd floor life skills 206 left CF	22030100-075CF	10/24/2025	1.1	Low			
3rd floor science room 205 Lab 1 CF	22030100-076CF	10/24/2025	ND	Low			
3rd floor science room 205 Lab 2 CF	22030100-077CF	10/24/2025	ND	Low			
3rd floor science room 205 Lab 3 CF	22030100-078CF	10/24/2025	ND	Low			
3rd floor science room 205 Lab 4 CF	22030100-079CF	10/24/2025	ND	Low			
3rd floor science room 205 Lab 5 CF	22030100-080CF	10/24/2025	ND	Low			
3rd floor science room 205 Lab 6 CF	22030100-081CF	10/24/2025	8.8	Low			
3rd floor girls bathroom BF	22030100-082BF	10/24/2025	ND	Low			
3rd floor boys bathroom BF	22030100-083BF	10/24/2025	ND	Low			
fitness center drinking fountain left DW	22030100-084DW	10/24/2025	ND	Low			
fitness center drinking fountain right DW	22030100-085DW	10/24/2025	ND	Low			
fitness water bottle filler right WB	22030100-086WB	10/24/2025	ND	Low			
new wing fitness center CF	22030100-087CF	10/24/2025	ND	Low			
ice machine new wing IM	22030100-090IM	10/24/2025	ND	Low			
ice machine old wing IM	22030100-091IM	10/24/2025	ND	Low			
new wing science eye wash OT	22030100-092OT	10/24/2025	13	Med			
old wing science eye wash OT	22030100-093OT	10/24/2025	3	Low			
football concession KF	22030100-094KF	10/24/2025	6.3	Low			
football bathroom boys BF	22030100-095BF	10/24/2025	ND	Low			
football girls bathroom BF	22030100-096BF	10/24/2025	ND	Low			
football spigot OS	22030100-097OS	10/24/2025	ND	Low			
new wing hallway drinking fountain east DW	22030100-098DW	10/24/2025	ND	Low			
new wing hallway water bottle east WB	22030100-099WB	10/24/2025	ND	Low			
new wing hallway drinking fountain west DW	22030100-100DW	10/24/2025	ND	Low			
boys drinking fountain locker room DW	22030100-101DW	10/24/2025	ND	Low			