

CLIENT INFORMANTION

Name: Chatham Central School District
Address: 50 Woodbridge Ave Chatham, NY 12037
Client Rep: Ethan Stalter

Date of Sampling:	2025
Samples Taken By:	Lisa Lyons
Samples Taken By:	

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	MED Elementary School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Ethan Stalter (518) 788-6264

SAMPLE DATA

Sample Description ID (ID must match container label)

Outlet Information

Lab Sample #	Level	MED Sample #	Location	Outlet Description	First Draw	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
1	Ground	MED-F-1	Kitchen	Pot Filler	x	MED-F-1	11/15/25 7:55	11/25/25 15:12	25K1896-01	Lead	8.16	5	ug/L
2	Ground	MED-F-2	Kitchen	Brazing Pan	x	MED-F-2	11/15/25 7:56	11/25/25 15:15	25K1896-02	Lead	8.56	5	ug/L
3	Ground	MED-F-3	Kitchen	Kettle	x	MED-F-3	11/15/25 7:57	11/25/25 15:17	25K1896-03	Lead	<2.00	5	ug/L
4	Ground	MED-KS-4	Kitchen	Prep Sink	x	MED-KS-4	11/15/25 7:58	11/25/25 15:19	25K1896-04	Lead	<2.00	5	ug/L
5	Ground	MED-F-5	Kitchen	Handwashing Sink	x	MED-F-5	11/15/25 7:59	11/25/25 15:22	25K1896-05	Lead	11.5	5	ug/L
6	Ground	MED-F-6	Kitchen	Veggie Washing Sink	x	MED-F-6	11/15/25 8:00	11/25/25 15:24	25K1896-06	Lead	<2.00	5	ug/L
7	Ground	MED-F-7	Kitchen	Veggie Washing Sink R	x								
8	Ground	MED-DW-8	Cafetorium	Water Fountain	x	MED-DW-8	11/15/25 8:06	11/25/25 15:27	25K1896-07	Lead	<2.00	5	ug/L
9	Ground	MED-F-9	Room 211	Sink Faucet	x	MED-F-9	11/15/25 8:11	11/25/25 15:29	25K1896-08	Lead	3.41	5	ug/L
10	Ground	MED-DW-10	Room 211	Classroom Water Fountain	x	MED-DW-10	11/15/25 8:12	11/25/25 14:58	25K1896-09	Lead	6.03	5	ug/L
11	Ground	MED-F-11	Room 212	classroom Sink Faucet	x	MED-F-11	11/15/25 8:13	11/25/25 15:31	25K1896-10	Lead	3.55	5	ug/L
12	Ground	MED-DW-12	Room 212	classroom Water Fountain	x	MED-DW-12	11/15/25 8:14	11/25/25 15:34	25K1896-11	Lead	6.77	5	ug/L
13	Ground	MED-F-13-R	Room 213	Classroom Right Sink Faucet	x	MED-F-13-R	11/15/25 8:16	11/25/25 15:41	25K1896-12	Lead	3.73	5	ug/L
14	Ground	MED-F-14-L	Room 213	Classroom Left Sink Faucet	x								
15	Ground	MED-DW-15	Room 213	Classroom Water Fountain	x	MED-DW-15	11/15/25 8:17	11/25/25 15:44	25K1896-13	Lead	3.19	5	ug/L
16	Ground	MED-F-16-R	Room 214	classroom Right Sink Faucet	x	MED-F-16-R	11/15/25 8:19	11/25/25 15:46	25K1896-14	Lead	<2.00	5	ug/L
17	Ground	MED-F-17-L	Room 214	classroom Left Sink Faucet	x								
18	Ground	MED-DW-18	Room 214	classroom Water Fountain	x	MED-DW-18	11/15/25 8:20	11/25/25 15:48	25K1896-15	Lead	10.1	5	ug/L
19	Ground	MED-F-19-R	Room 215	Classroom Right Sink Faucet	x	MED-F-19-R	11/15/25 8:21	11/25/25 15:51	25K1896-16	Lead	<2.00	5	ug/L
20	Ground	MED-F-20-L	Room 215	Classroom Left Sink Faucet	x	MED-F-20-L	11/15/25 8:22	11/25/25 15:53	25K1896-17	Lead	<2.00	5	ug/L
21	Ground	MED-DW-21	Room 215	Classroom Water Fountain	x	MED-DW-21	11/15/25 8:23	11/25/25 15:56	25K1896-18	Lead	3.83	5	ug/L
22	Ground	MED-DW-22	Lobby Between Rest Rooms	Water Fountain	x	MED-DW-22	11/15/25 8:24	11/25/25 15:58	25K1896-19	Lead	<2.00	5	ug/L
23	Ground	MED-DW-23	Lobby Between Rest Rooms	Bottle Filler	x	MED-DW-23	11/15/25 8:25	11/25/25 16:00	25K1896-20	Lead	<2.00	5	ug/L
24	Ground	MED-F-24	Custodial Break Room	Sink Faucet	x	MED-F-24	11/15/25 8:26	11/25/25 16:22	25K1896-21	Lead	5.4	5	ug/L
25	Ground	MED-F-25-R	Room 218	Classroom Right Sink Faucet	x	MED-F-25-R	11/15/25 8:27	11/25/25 16:25	25K1896-22	Lead	2.21	5	ug/L
26	Ground	MED-F-26-L	Room 218	Classroom Left Sink Faucet	x	MED-F-26-L	11/15/25 8:28	11/25/25 16:27	25K1896-23	Lead	<2.00	5	ug/L
27	Ground	MED-DW-27	Room 218	Classroom Water Fountain	x	MED-DW-27	11/15/25 8:29	11/25/25 16:13	25K1896-24	Lead	2.59	5	ug/L
28	Ground	MED-F-28	Room 219	Right Sink Faucet	x	MED-F-28	11/15/25 8:30	11/25/25 16:29	25K1896-25	Lead	20.5	5	ug/L
29	Ground	MED-F-29	Room 219	Left Sink Faucet	x	MED-F-29	11/15/25 8:31	11/25/25 16:32	25K1896-26	Lead	12.5	5	ug/L
30	Ground	MED-DW-30	Room 219	Water Fountain	x	MED-DW-30	11/15/25 8:32	11/25/25 16:39	25K1896-27	Lead	2.02	5	ug/L
31	Ground	MED-F-31-R	Room 220	Classroom Right Sink Faucet	x	MED-F-31-R	11/15/25 8:33	11/25/25 16:41	25K1896-28	Lead	<2.00	5	ug/L
32	Ground	MED-F-32-L	Room 220	Classroom Left Sink Faucet	x	MED-F-32-L	11/15/25 8:34	11/25/25 16:44	25K1896-29	Lead	<2.00	5	ug/L
33	Ground	MED-DW-33	Room 220	Classroom Water Fountain	x	MED-DW-33	11/15/25 8:35	11/25/25 16:46	25K1896-30	Lead	<2.00	5	ug/L
34	Ground	MED-F-34	Room 221	Right Sink Faucet	x								
35	Ground	MED-F-35	Room 221	Left Sink Faucet	x	MED-F-35	11/15/25 8:36	11/25/25 16:48	25K1896-31	Lead	3.01	5	ug/L
36	Ground	MED-DW-36	Room 221	Water Fountain	x	MED-DW-36	11/15/25 8:37	11/25/25 16:51	25K1896-32	Lead	<2.00	5	ug/L
37	Ground	MED-F-37	Room 222	Classroom Right Sink Faucet	x	MED-F-37	11/15/25 8:38	11/25/25 16:53	25K1896-33	Lead	<2.00	5	ug/L
38	Ground	MED-F-38	Room 222	Classroom Left Sink Faucet	x	MED-F-38	11/15/25 8:39	11/25/25 16:56	25K1896-34	Lead	<2.00	5	ug/L
39	Ground	MED-DW-39	Room 222	Classroom Water Fountain	x	MED-DW-39	11/15/25 8:40	11/25/25 16:58	25K1896-35	Lead	<2.00	5	ug/L

Lab Sample #	Level	MED Sample #	Location	Outlet Description	First Draw	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
40	Ground	MED-F-40-R	Room 223	Right Sink Faucet	x	MED-F-40-R	11/15/25 8:41	11/25/25 17:00	25K1896-36	Lead	<2.00	5	ug/L
41	Ground	MED-F-41-L	Room 223	Left Sink Faucet	x	MED-F-41-L	11/15/25 8:42	11/25/25 17:08	25K1896-37	Lead	<2.00	5	ug/L
42	Ground	MED-DW-42	Room 223	Water Fountain	x	MED-DW-42	11/15/25 8:43	11/25/25 17:10	25K1896-38	Lead	<2.00	5	ug/L
43	Ground	MED-F-43-R	Room 224	Classroom Right Sink Faucet	x	MED-F-43-R	11/15/25 8:44	11/25/25 17:12	25K1896-39	Lead	<2.00	5	ug/L
44	Ground	MED-F-44-L	Room 224	Classroom Left Sink Faucet	x	MED-F-44-L	11/15/25 8:45	11/25/25 17:15	25K1896-40	Lead	<2.00	5	ug/L
45	Ground	MED-DW-45	Room 224	Classroom Water Fountain	x	MED-DW-45	11/15/25 8:46	11/25/25 17:36	25K1896-41	Lead	<2.00	5	ug/L
46	Ground	MED-F-46-R	Room 225	Right Sink Faucet	x	MED-F-46-R	11/15/25 8:47	11/25/25 17:39	25K1896-42	Lead	<2.00	5	ug/L
47	Ground	MED-F-47-L	Room 225	Left Sink Faucet	x	MED-F-47-L	11/15/25 8:48	11/25/25 17:41	25K1896-43	Lead	<2.00	5	ug/L
48	Ground	MED-DW-48	Room 225	Water Fountain	x	MED-DW-48	11/15/25 8:49	11/25/25 17:43	25K1896-44	Lead	<2.00	5	ug/L
49	Ground	MED-F-49-R	Room 226	Classroom Right Sink Faucet	x	MED-F-49-R	11/15/25 9:08	11/25/25 17:46	25K1896-45	Lead	2.1	5	ug/L
50	Ground	MED-F-50-L	Room 226	Classroom Left Sink Faucet	x	MED-F-50-L	11/15/25 9:09	11/25/25 17:48	25K1896-46	Lead	<2.00	5	ug/L
51	Ground	MED-DW-51	Room 226	Classroom Water Fountain	x	MED-DW-51	11/15/25 9:10	11/25/25 17:50	25K1896-47	Lead	<2.00	5	ug/L
52	Ground	MED-F-52	Room 227	Right Sink Faucet	x	MED-F-52	11/15/25 9:11	11/25/25 17:53	25K1896-48	Lead	<2.00	5	ug/L
53	Ground	MED-F-53	Room 227	Left Sink Faucet	x	MED-F-53	11/15/25 9:12	11/25/25 17:55	25K1896-49	Lead	<2.00	5	ug/L
54	Ground	MED-DW-54	Room 227	Water Fountain	x	MED-DW-54	11/15/25 9:13	11/25/25 17:58	25K1896-50	Lead	<2.00	5	ug/L
55	Ground	MED-F-55-R	Room 228	Classroom Right Sink Faucet	x	MED-F-55-R	11/15/25 9:14	11/25/25 17:22	25K1896-51	Lead	<2.00	5	ug/L
56	Ground	MED-F-56-L	Room 228	Classroom Left Sink Faucet	x	MED-F-56-L	11/15/25 9:15	11/25/25 18:05	25K1896-52	Lead	<2.00	5	ug/L
57	Ground	MED-DW-57	Room 228	Classroom Water Fountain	x	MED-DW-57	11/15/25 9:16	11/25/25 18:07	25K1896-53	Lead	<2.00	5	ug/L
58	Ground	MED-DW-58	Corridor Outside room 229	Water Fountain	x								
59	Ground	MED-DW-59	Corridor Outside room 229	Bottle Filler	x	MED-DW-59	11/15/25 9:17	11/25/25 18:10	25K1896-54	Lead	<2.00	5	ug/L
60	Ground	MED-F-60-R	Room 230	Classroom Right Sink Faucet	x	MED-F-60-R	11/15/25 9:18	11/25/25 18:12	25K1896-55	Lead	<2.00	5	ug/L
61	Ground	MED-F-61-L	Room 230	Classroom Left Sink Faucet	x	MED-F-61-L	11/15/25 9:19	11/25/25 18:14	25K1896-56	Lead	<2.00	5	ug/L
62	Ground	MED-DW-62	Room 230	Classroom Water Fountain	x	MED-DW-62	11/15/25 9:20	11/25/25 18:17	25K1896-57	Lead	<2.00	5	ug/L
63	Ground	MED-F-63-R	Room 231	Right Sink Faucet	x	MED-F-63-R	11/15/25 9:21	11/25/25 18:19	25K1896-58	Lead	<2.00	5	ug/L
64	Ground	MED-F-64-L	Room 231	Left Sink Faucet	x	MED-F-64-L	11/15/25 9:22	11/25/25 18:21	25K1896-59	Lead	<2.00	5	ug/L
65	Ground	MED-DW-65	Room 231	Water Fountain	x	MED-DW-65	11/15/25 9:23	11/25/25 18:24	25K1896-60	Lead	<2.00	5	ug/L
66	Ground	MED-F-66-R	Room 232	Classroom Right Sink Faucet	x	MED-F-66-R	11/15/25 9:24	11/25/25 18:45	25K1896-61	Lead	<2.00	5	ug/L
67	Ground	MED-F-67-L	Room 232	Classroom Left Sink Faucet	x	MED-F-67-L	11/15/25 9:25	11/25/25 18:47	25K1896-62	Lead	<2.00	5	ug/L
68	Ground	MED-DW-68	Room 232	Classroom Water Fountain	x	MED-DW-68	11/15/25 9:26	11/25/25 18:50	25K1896-63	Lead	<2.00	5	ug/L
69	Ground	MED-DW-69	Room 245 Faculty Room	Sink Faucet	x	MED-DW-69	11/15/25 9:37	11/25/25 18:52	25K1896-64	Lead	4.99	5	ug/L
70	Ground	MED-F-70	Nurse's Office Sink basin	Sink Faucet	x	MED-F-70	11/15/25 9:35	11/25/25 18:55	25K1896-65	Lead	3.27	5	ug/L
71	Ground	MED-F-71	Nurses office Ice Maker	Ice Maker	x	MED-F-71	11/15/25 9:36	11/25/25 19:02	25K1896-66	Lead	13.9	5	ug/L
72	Ground	MED-DW-72	Corridor Across from Room 302	Water Fountain	x	MED-DW-72	11/15/25 9:39	11/25/25 19:04	25K1896-67	Lead	2.82	5	ug/L
73	Ground	MED-F-73	Room 303	Sink Faucet	x	MED-F-73	11/15/25 9:40	11/25/25 19:07	25K1896-68	Lead	12.8	5	ug/L
74	Ground	MED-DW-74	Room 303	Water Fountain	x	MED-DW-74	11/15/25 9:41	11/25/25 19:09	25K1896-69	Lead	53.9	5	ug/L
75	Ground	MED-F-75	Room 304	Sink Faucet	x	MED-F-75	11/15/25 9:42	11/25/25 19:11	25K1896-70	Lead	15.3	5	ug/L
76	Ground	MED-DW-76	Room 304	Water Fountain	x	MED-DW-76	11/15/25 9:43	11/25/25 19:14	25K1896-71	Lead	10.2	5	ug/L
77	Ground	MED-F-77	Outside Room 305A	Special Ed Sink Faucet	x	MED-F-77	11/15/25 9:44	11/25/25 19:16	25K1896-72	Lead	12.4	5	ug/L
78	Ground	MED-DW-78	Outside Room 305A	Special Ed Water Fountain	x	MED-DW-78	11/15/25 9:45	11/25/25 19:18	25K1896-73	Lead	34.1	5	ug/L
79	Ground	MED-F-79	Room 306	Sink Faucet	x	MED-F-79	11/15/25 9:46	11/25/25 19:21	25K1896-74	Lead	23.9	5	ug/L
80	Ground	MED-DW-80	Room 306	Water Fountain	x	MED-DW-80	11/15/25 9:47	11/25/25 19:23	25K1896-75	Lead	21.7	5	ug/L
81	Ground	MED-F-81-R	Room 307	Right Sink Faucet	x	MED-F-81-R	11/15/25 9:48	11/25/25 19:30	25K1896-76	Lead	5.33	5	ug/L
82	Ground	MED-F-82-L	Room 307	Left Sink Faucet	x	MED-F-82-L	11/15/25 9:49	11/25/25 18:36	25K1896-77	Lead	8.03	5	ug/L
83	Ground	MED-DW-83	Room 307	Water Fountain	x	MED-DW-83	11/15/25 9:50	11/25/25 19:33	25K1896-78	Lead	20.2	5	ug/L
84	Ground	MED-F-84	Room 308	Sink Faucet	x	MED-F-84	11/15/25 9:51	11/25/25 19:35	25K1896-79	Lead	6.84	5	ug/L
85	Ground	MED-DW-85	Room 308	Water Fountain	x	MED-DW-85	11/15/25 9:52	11/25/25 19:37	25K1896-80	Lead	9.18	5	ug/L
86	Ground	MED-F-86	Room 309	Sink Faucet	x	MED-F-86	11/15/25 9:53	11/25/25 19:59	25K1896-81	Lead	4.05	5	ug/L
87	Ground	MED-DW-87	Room 309	Water Fountain	x	MED-DW-87	11/15/25 9:54	11/25/25 20:01	25K1896-82	Lead	2.02	5	ug/L
88	Ground	MED-F-88	Room 310	Sink Faucet	x	MED-F-88	11/15/25 9:55	11/25/25 20:03	25K1896-83	Lead	<2.00	5	ug/L

Lab Sample #	Level	MED Sample #	Location	Outlet Description		First Draw	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
89	Ground	MED-DW-89	Room 310		Water Fountain	x	MED-DW-89	11/15/25 9:56	11/25/25 20:06	25K1896-84	Lead	<2.00	5	ug/L
90	Ground	MED-F-90	Room 311		Sink Faucet	x	MED-F-90	11/15/25 9:57	11/25/25 20:08	25K1896-85	Lead	<2.00	5	ug/L
91	Ground	MED-DW-91	Room 311		Water Fountain	x	MED-DW-91	11/15/25 9:58	11/25/25 20:11	25K1896-86	Lead	181	5	ug/L
92	Ground	MED-F-92	Room 312		Sink Faucet	x	MED-F-92	11/15/25 9:59	11/25/25 20:13	25K1896-87	Lead	9.32	5	ug/L
93	Ground	MED-DW-93	Room 312		Water Fountain	x	MED-DW-93	11/15/25 10:00	11/25/25 20:15	25K1896-88	Lead	7.03	5	ug/L
94	Ground	MED-F-94	Room 313		Sink Faucet	x	MED-F-94	11/15/25 10:01	11/25/25 19:44	25K1896-89	Lead	6.37	5	ug/L
95	Ground	MED-DW-95	Room 313		Water Fountain	x	MED-DW-95	11/15/25 10:02	11/25/25 20:18	25K1896-90	Lead	12.1	5	ug/L
96	Ground	MED-F-96	Room 316		Sink Faucet	x	MED-F-96	11/15/25 10:03	11/25/25 20:20	25K1896-91	Lead	11.7	5	ug/L
97	Ground	MED-DW-97	Room 316		Water Fountain	x	MED-DW-97	11/15/25 10:04	11/25/25 20:27	25K1896-92	Lead	44.7	5	ug/L
98	Ground	MED-DW-98-L	Corridor outside room 314/5 bathrooms		Water Fountain Left	x	MED-DW-98-L	11/15/25 10:05	11/25/25 20:29	25K1896-93	Lead	<2.00	5	ug/L
99	Ground	MED-DW-99-R	Corridor outside room 314/5 bathrooms		Water Fountain Right	x	MED-DW-99-R	11/15/25 10:06	11/25/25 20:32	25K1896-94	Lead	<2.00	5	ug/L
100	Lower Level	MED-F-100	Room 101	Head Start Classroom	Sink Faucet	x	MED-F-100	11/15/25 9:01	11/25/25 20:34	25K1896-95	Lead	41.3	5	ug/L
101	Lower Level	MED-F-101	Room 101	Head Start Classroom	Sink Faucet	x	MED-F-101	11/15/25 9:00	11/25/25 20:37	25K1896-96	Lead	23.3	5	ug/L
102	Lower Level	MED-F-102	Room 102	Conference Room	Sink Faucet	x	MED-F-102	11/15/25 8:59	11/25/25 20:39	25K1896-97	Lead	11.2	5	ug/L
103	Lower Level	MED-F-103	Room 103	Office	Sink Faucet	x	MED-F-103	11/15/25 8:58	11/25/25 20:41	25K1896-98	Lead	6.98	5	ug/L
104	Lower Level	MED-F-104	Room 104	Office	Sink Faucet	x	MED-F-104	11/15/25 8:54	11/25/25 20:44	25K1896-99	Lead	3.05	5	ug/L
105	Lower Level	MED-F-105	Room 105	Office	Sink Faucet	x	MED-F-105	25K1934-01	11/15/25 8:53	11/26/25 11:20	Lead	3.94	5	ug/L
106	Lower Level	MED-F-106	Room 106	OT/PT	Sink Faucet	x	MED-F-106	25K1934-02	11/15/25 8:52	11/26/25 11:23	Lead	11.1	5	ug/L
107	Lower Level	MED-F-107	Room 107	Orchestra	Sink Faucet	x	MED-F-107	25K1934-03	11/15/25 8:51	11/26/25 11:30	Lead	2.44	5	ug/L
108	Lower Level	MED-F-108	Room 108	Band	Sink Faucet	x	MED-F-108	25K1934-04	11/15/25 8:50	11/26/25 11:32	Lead	<2.00	5	ug/L
109	Ground	MED-F-109	Room 210 Old Library Prep		Sink Faucet	x	MED-F-109	25K1934-05	11/15/25 8:08	11/26/25 11:34	Lead	43.9	5	ug/L
110	Ground	MED-DW-110	Basement Corridor		Water Fountain	x	MED-DW-110	25K1934-06	11/15/25 9:02	11/26/25 11:37	Lead	10.7	5	ug/L
111	Ground	MED-F-111	Room 229 Sink Left		Sink Faucet	x	MED-F-111	25K1934-07	11/15/25 9:18	11/26/25 11:39	Lead	36.3	5	ug/L
112	Ground	MED-F-112	Room 229 Sink Right		Sink Faucet	x	MED-F-112	25K1934-08	11/15/25 9:19	11/26/25 11:41	Lead	4.24	5	ug/L
113	Ground	MED-F-113	Main Office		Sink Faucet	x	MED-F-113	25K1934-09	11/15/25 9:28	11/26/25 11:44	Lead	9.53	5	ug/L
114	Ground	MED-DW-114	Bottle Filler across from 305		Bottle Filler	x	MED-DW-114	25K1934-10	11/15/25 10:07	11/26/25 11:46	Lead	<2.00	5	ug/L