(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 

**Sample ID:** **AW05557**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 1

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-F-1 Al-s Bathroom

*Collect Date:* 04/26/2016
*Collect Time:* 05:15
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

*Comments:*
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 

**Sample ID:** **AW05558**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 2

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-F-2 Womens Breakroom

*Collect Date:* 04/26/2016
*Collect Time:* 05:13
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05559**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 3

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-F-3 Mens Breakroom

*Collect Date:* 04/26/2016
*Collect Time:* 05:12
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05560**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 4

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-F-4 Breakroom

*Collect Date:* 04/26/2016
*Collect Time:* 05:11
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.38 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05561**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 5

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-DW-5 Breakroom

*Collect Date:* 04/26/2016
*Collect Time:* 05:10
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.12 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05562**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 6

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-F-6 Maint. Breakroom

*Collect Date:* 04/26/2016
*Collect Time:* 05:08
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05563**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 7

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-F-7 Maint. Shop

*Collect Date:* 04/26/2016
*Collect Time:* 05:07
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05564**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/12/2016
*PO Number:*
*Your Ref:* Lab Sample 8

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave Bus Garage
*Sample Pt:* BG-DW-8 Maint. Shop

*Collect Date:* 04/26/2016
*Collect Time:* 05:06
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.46 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016
**Sample ID:** **AW05565**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 1

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-1 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.24 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.001 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 

**Sample ID:** **AW05566**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 2

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-2 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016

**Sample ID:** **AW05567**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 3

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-3 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:26
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05569**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 4

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-4 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:23
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.43 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.017 | 0.015 | X | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05570**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 5

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-5 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**



**Printed On** 5/12/2016
**Sample ID:** **AW05571**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 6

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-6 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016

**Sample ID:** **AW05572**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 7

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-7 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05574**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 8

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-8 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 05:29
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05575**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 9

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-9 Cafe

*Collect Date:* 04/26/2016
*Collect Time:* 05:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016

**Sample ID:** **AW05577**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 10

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-10 room221

*Collect Date:* 04/26/2016
*Collect Time:* 07:25
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.17 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.020 | 0.015 | X | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016

**Sample ID:** **AW05578**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 11

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-11 room221

*Collect Date:* 04/26/2016
*Collect Time:* 07:25
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016

**Sample ID:** **AW05579**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 12

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-12 room212

*Collect Date:* 04/26/2016
*Collect Time:* 07:21
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05582**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 13

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-13 room212

*Collect Date:* 04/26/2016
*Collect Time:* 07:21
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.016 | 0.015 | X | mg/l | SM3113B | BPC | 4/29/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05583**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 14

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-14 room 213

*Collect Date:* 04/26/2016
*Collect Time:* 07:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05584**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 15

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-15 room 213

*Collect Date:* 04/26/2016
*Collect Time:* 07:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 Page 1 of 1

**Sample ID:** **AW05585**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 16

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-16 room 214

*Collect Date:* 04/26/2016
*Collect Time:* 07:19
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.13 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/12/2016 

**Sample ID:** **AW05586**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/11/2016
*PO Number:*
*Your Ref:* Lab Sample 17

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-17 room214

*Collect Date:* 04/26/2016
*Collect Time:* 07:19
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.24 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05588**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 18

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-18 room215

*Collect Date:* 04/26/2016
*Collect Time:* 07:10
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05592**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 20

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-20 Library

*Collect Date:* 04/26/2016
*Collect Time:* 05:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.032 | 0.015 | X | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**



**Printed On** 5/25/2016
**Sample ID:** **AW05593**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 21

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-21 Girls Bath-Library

*Collect Date:* 04/26/2016
*Collect Time:* 05:36
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 

**Sample ID:** **AW05594**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 22

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-22 Boys Bath-Library

*Collect Date:* 04/26/2016
*Collect Time:* 05:36
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05595**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 23

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-23 Mens-Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 05:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.034 | 0.015 | X | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05596**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 24

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-24 Mens-Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 05:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05597**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 25

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-25 Ladies Bath-Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 05:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.11 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05598**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 26

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-26 Ladies Bath-Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 05:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 

**Sample ID:** **AW05601**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 27

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-27 Lobby Drinking Fountain

*Collect Date:* 04/26/2016
*Collect Time:* 05:37
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 

**Sample ID:** **AW05602**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 28

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-28 Custodial

*Collect Date:* 04/26/2016
*Collect Time:* 05:41
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05603**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 29

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-29 Room218

*Collect Date:* 04/26/2016
*Collect Time:* 05:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 4/29/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/1/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 

**Sample ID:** **AW05604**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 30

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-30 Room218

*Collect Date:* 04/26/2016
*Collect Time:* 05:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05605**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 31

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-31 Room232

*Collect Date:* 04/26/2016
*Collect Time:* 05:44
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.41 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05606**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 32

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-32 Room232

*Collect Date:* 04/26/2016
*Collect Time:* 05:44
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05607**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 33

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-33 Room231

*Collect Date:* 04/26/2016
*Collect Time:* 05:45
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05608**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 34

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-34 Room231

*Collect Date:* 04/26/2016
*Collect Time:* 05:45
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05609**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 35

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-35 Room219

*Collect Date:* 04/26/2016
*Collect Time:* 05:46
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05610**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 36

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-36 Room219

*Collect Date:* 04/26/2016
*Collect Time:* 05:46
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.14 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05611**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 37

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-37 Room220

*Collect Date:* 04/26/2016
*Collect Time:* 05:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05612**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 38

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-38 Room 220

*Collect Date:* 04/26/2016
*Collect Time:* 05:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05613**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 39

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-39 Room230

*Collect Date:* 04/26/2016
*Collect Time:* 05:48
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05614**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 40

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-40 Room229

*Collect Date:* 04/26/2016
*Collect Time:* 05:52
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.046 | 0.015 | X | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016

**Sample ID:** **AW05615**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 41

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-41 Hallway-221

*Collect Date:* 04/26/2016
*Collect Time:* 05:55
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05616**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 42

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-42 Room221

*Collect Date:* 04/26/2016
*Collect Time:* 05:54
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.62 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05617**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 43

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-43 Room221

*Collect Date:* 04/26/2016
*Collect Time:* 05:54
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016

**Sample ID:** **AW05618**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 44

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-44 Room221

*Collect Date:* 04/26/2016
*Collect Time:* 05:53
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016

**Sample ID:** **AW05619**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 45

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-45 Room222

*Collect Date:* 04/26/2016
*Collect Time:* 06:01
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05620**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 46

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-46 Room222

*Collect Date:* 04/26/2016
*Collect Time:* 06:01
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 

**Sample ID:** **AW05621**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 47

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-47 Room228

*Collect Date:* 04/26/2016
*Collect Time:* 06:05
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05622**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 48

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-48 Room228

*Collect Date:* 04/26/2016
*Collect Time:* 06:05
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05623**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 49

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-49 room224

*Collect Date:* 04/26/2016
*Collect Time:* 06:09
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05624**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 50

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-50 room224

*Collect Date:* 04/26/2016
*Collect Time:* 06:09
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.18 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05625**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 51

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-51 Room227

*Collect Date:* 04/26/2016
*Collect Time:* 06:06
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016

**Sample ID:** **AW05626**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 52

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-52 Room227

*Collect Date:* 04/26/2016
*Collect Time:* 06:06
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05627**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 53

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-53 Room226

*Collect Date:* 04/26/2016
*Collect Time:* 06:10
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.24 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05628**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 54

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-54 Room226

*Collect Date:* 04/26/2016
*Collect Time:* 06:10
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05629**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 55

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-55 Room225

*Collect Date:* 04/26/2016
*Collect Time:* 06:11
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05630**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 56

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-56 Room225

*Collect Date:* 04/26/2016
*Collect Time:* 06:11
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.17 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | BPC | 5/4/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05631**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 57

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-57 Supt. Conf. Bath

*Collect Date:* 04/26/2016
*Collect Time:* 06:14
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.024 | 0.015 | X | mg/l | SM3113B | BPC | 5/9/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05632**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 58

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-58 Faculty

*Collect Date:* 04/26/2016
*Collect Time:* 06:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/5/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05633**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 59

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-59 Faculty

*Collect Date:* 04/26/2016
*Collect Time:* 06:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016

**Sample ID:** **AW05634**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 60

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-60 Nurse

*Collect Date:* 04/26/2016
*Collect Time:* 06:16
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.18 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05635**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 61

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-61 Nurse

*Collect Date:* 04/26/2016
*Collect Time:* 06:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.37 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05636**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 62

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-NI-62 Nurse Ice Machine

*Collect Date:* 04/26/2016
*Collect Time:* 06:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05637**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 63

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-63 Hallway-Gym

*Collect Date:* 04/26/2016
*Collect Time:* 06:25
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016

**Sample ID:** **AW05638**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 64

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-64 Gym Office

*Collect Date:* 04/26/2016
*Collect Time:* 06:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05639**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 65

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-65 Girls Bath-302

*Collect Date:* 04/26/2016
*Collect Time:* 06:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.36 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.018 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 

**Sample ID:** **AW05640**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 66

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-66 Girls Bath-302

*Collect Date:* 04/26/2016
*Collect Time:* 06:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05641**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 67

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-67 Boys Bath-302

*Collect Date:* 04/26/2016
*Collect Time:* 06:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.016 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05642**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 68

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-68 Boys Bath-302

*Collect Date:* 04/26/2016
*Collect Time:* 06:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.025 | 0.015 | X | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05643**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 69

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-69 Room303

*Collect Date:* 04/26/2016
*Collect Time:* 06:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.011 | 0.015 | | mg/l | SM3113B | BPC | 5/9/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05644**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 70

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-70 Room303

*Collect Date:* 04/26/2016
*Collect Time:* 06:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05645**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 71

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-71 Room317

*Collect Date:* 04/26/2016
*Collect Time:* 06:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.016 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05646**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 72

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-72 Room317

*Collect Date:* 04/26/2016
*Collect Time:* 06:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05647**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 73

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-73 room304

*Collect Date:* 04/26/2016
*Collect Time:* 06:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05648**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 74

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-74 room304

*Collect Date:* 04/26/2016
*Collect Time:* 06:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05649**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 75

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-75 room316

*Collect Date:* 04/26/2016
*Collect Time:* 06:34
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05650**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 76

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-76 room316

*Collect Date:* 04/26/2016
*Collect Time:* 06:34
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05651**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 77

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-77 room305

*Collect Date:* 04/26/2016
*Collect Time:* 06:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.024 | 0.015 | X | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05652**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 79

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-79 room306

*Collect Date:* 04/26/2016
*Collect Time:* 06:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016

**Sample ID:** **AW05653**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 80

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-80 room306

*Collect Date:* 04/26/2016
*Collect Time:* 06:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05654**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 81

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-81 room313

*Collect Date:* 04/26/2016
*Collect Time:* 06:41
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05655**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 82

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-82 room313

*Collect Date:* 04/26/2016
*Collect Time:* 06:41
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.023 | 0.015 | X | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05656**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 83

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-83 Hallway-88 wing

*Collect Date:* 04/26/2016
*Collect Time:* 06:36
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.17 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016
**Sample ID:** **AW05657**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 84

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-84 Hallway-88 wing

*Collect Date:* 04/26/2016
*Collect Time:* 06:36
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.17 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05658**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 85

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-85 Girls Bath-88 wing

*Collect Date:* 04/26/2016
*Collect Time:* 06:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.42 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05659**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 86

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-86 Girls Bath-88 wing

*Collect Date:* 04/26/2016
*Collect Time:* 06:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.46 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.011 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05660**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 87

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-87 Boys Bath-88 wing

*Collect Date:* 04/26/2016
*Collect Time:* 06:37
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.58 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.022 | 0.015 | X | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05661**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 88

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-88 Boys Bath-88 wing

*Collect Date:* 04/26/2016
*Collect Time:* 06:37
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05663**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 89

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-89 room307

*Collect Date:* 04/26/2016
*Collect Time:* 06:44
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.024 | 0.015 | X | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05664**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 90

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-90 room307

*Collect Date:* 04/26/2016
*Collect Time:* 06:44
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05665**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 91

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-91 room312

*Collect Date:* 04/26/2016
*Collect Time:* 06:43
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.020 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05666**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 92

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-92 room312

*Collect Date:* 04/26/2016
*Collect Time:* 06:43
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 5/25/2016 Page 1 of 1

**Sample ID:** **AW05667**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 05/25/2016
*PO Number:*
*Your Ref:* Lab Sample 93

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-93 room311

*Collect Date:* 04/26/2016
*Collect Time:* 06:48
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | BPC | 5/5/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05668**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 94

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-94 room311

*Collect Date:* 04/26/2016
*Collect Time:* 06:48
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | BPC | 5/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05669**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 95

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-95 room308

*Collect Date:* 04/26/2016
*Collect Time:* 06:47
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | BPC | 5/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05670**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 96

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-96 room308

*Collect Date:* 04/26/2016
*Collect Time:* 06:47
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/6/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | BPC | 5/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05671**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 97

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-97 room310

*Collect Date:* 04/26/2016
*Collect Time:* 06:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.016 | 0.015 | X | mg/l | SM3113B | BPC | 5/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05672**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 98

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-98 room310

*Collect Date:* 04/26/2016
*Collect Time:* 06:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | BPC | 5/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05673**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 99

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-99 room309

*Collect Date:* 04/26/2016
*Collect Time:* 06:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | BPC | 5/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05674**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 100

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-100 room309

*Collect Date:* 04/26/2016
*Collect Time:* 06:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.36 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.017 | 0.015 | X | mg/l | SM3113B | BPC | 5/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05675**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 101

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-101 room101

*Collect Date:* 04/26/2016
*Collect Time:* 07:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.018 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05676**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 102

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-102 room101

*Collect Date:* 04/26/2016
*Collect Time:* 07:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05677**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 103

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-103 room102

*Collect Date:* 04/26/2016
*Collect Time:* 07:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.011 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05678**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 104

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-104 room102

*Collect Date:* 04/26/2016
*Collect Time:* 07:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.13 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.001 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05679**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 105

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-105 room103

*Collect Date:* 04/26/2016
*Collect Time:* 07:41
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.36 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05680**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 107

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-107 room104

*Collect Date:* 04/26/2016
*Collect Time:* 07:43
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.018 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05681**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 108

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-108 room105

*Collect Date:* 04/26/2016
*Collect Time:* 07:46
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.016 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05682**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 109

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-109 room106

*Collect Date:* 04/26/2016
*Collect Time:* 07:46
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05683**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 110

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-110 room107

*Collect Date:* 04/26/2016
*Collect Time:* 07:47
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.022 | 0.015 | X | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05684**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 111

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-111 room108

*Collect Date:* 04/26/2016
*Collect Time:* 07:48
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05685**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 112

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-DW-112 Hallway-downstairs

*Collect Date:* 04/26/2016
*Collect Time:* 07:43
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05686**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 113

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-113 Boys Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:59
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05687**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 114

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-114 Boys Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:59
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05688**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 115

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-115 Boys Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:59
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05689**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 116

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-116 Boys Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:59
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.64 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.050 | 0.015 | X | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05690**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 117

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-117 Girls Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:57
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05691**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 118

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-118 Girls Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:57
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05692**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 119

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-119 Girls Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:57
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05693**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 120

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MED Elementary School
*Sample Pt:* MED-F-120 Girls Bath-229

*Collect Date:* 04/26/2016
*Collect Time:* 05:57
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.20 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW06005**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 121

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-121 Main Office Sink

*Collect Date:* 04/26/2016
*Collect Time:* 06:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06006**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 122

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-122 310

*Collect Date:* 04/26/2016
*Collect Time:* 06:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06007**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 123

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-123 307

*Collect Date:* 04/26/2016
*Collect Time:* 06:44
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.38 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06008**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 124

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-124 Down Stairs Hall Bath

*Collect Date:* 04/26/2016
*Collect Time:* 07:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.43 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06009**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 126

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-126 212 F Bathroom

*Collect Date:* 04/26/2016
*Collect Time:* 07:21
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.18 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.021 | 0.015 | M+X | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06010**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 127

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-127 211 F Bathroom

*Collect Date:* 04/26/2016
*Collect Time:* 07:25
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.13 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06011**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 128

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-DW-128 223

*Collect Date:* 04/26/2016
*Collect Time:* 06:03
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.15 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.001 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06012**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 129

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-129 223

*Collect Date:* 04/26/2016
*Collect Time:* 06:03
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06013**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 130

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-130 Art

*Collect Date:* 04/26/2016
*Collect Time:* 06:57
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.38 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06014**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 131

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-131 Art

*Collect Date:* 04/26/2016
*Collect Time:* 07:51
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.40 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06015**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 132

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-132 215

*Collect Date:* 04/26/2016
*Collect Time:* 07:10
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.15 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06016**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 133

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-133 229

*Collect Date:* 04/26/2016
*Collect Time:* 07:36
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.18 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.018 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06018**
*Date Received:* 04/26/2016
*Time Received:* 14:30
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 134

*Customer:* Chatham Central School
*Owner:* Chatham MED Elementary School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MED-F-134 220

*Collect Date:* 04/26/2016
*Collect Time:* 07:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05694**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 1

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-1 GA2

*Collect Date:* 04/26/2016
*Collect Time:* 09:54
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.58 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.018 | 0.015 | X | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05695**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 2

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-2 GA1

*Collect Date:* 04/26/2016
*Collect Time:* 09:52
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 

**Sample ID:** **AW05696**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 3

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-3 GA1

*Collect Date:* 04/26/2016
*Collect Time:* 09:51
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05697**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 4

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-4 GA3

*Collect Date:* 04/26/2016
*Collect Time:* 09:53
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05698**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 5

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-5 GA3

*Collect Date:* 04/26/2016
*Collect Time:* 09:52
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.24 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05699**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 6

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-6 Hallway-GA6

*Collect Date:* 04/26/2016
*Collect Time:* 09:55
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.51 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.034 | 0.015 | X | mg/l | SM3113B | HSN | 5/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 

**Sample ID:** **AW05700**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 7

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-7 Public Library-conf.

*Collect Date:* 04/26/2016
*Collect Time:* 10:00
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05702**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 8

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-8 Public Library-Grd. Floor

*Collect Date:* 04/26/2016
*Collect Time:* 10:00
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05703**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 9

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-9 Public Library-Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 10:02
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05704**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 10

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-10 GB2

*Collect Date:* 04/26/2016
*Collect Time:* 10:07
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.49 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 

**Sample ID:** **AW05705**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 11

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-11 GB2

*Collect Date:* 04/26/2016
*Collect Time:* 10:07
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.45 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05706**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 12

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-12 GB1

*Collect Date:* 04/26/2016
*Collect Time:* 10:09
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.44 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05707**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 13

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-13 GB1

*Collect Date:* 04/26/2016
*Collect Time:* 10:08
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.42 | 1.3 | | mg/L | SM3111B | NSS | 5/9/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05709**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 14

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-14 GB4

*Collect Date:* 04/26/2016
*Collect Time:* 10:11
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.40 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05710**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 15

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-15 GB4

*Collect Date:* 04/26/2016
*Collect Time:* 10:12
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.46 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05711**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 16

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-16 GB6

*Collect Date:* 04/26/2016
*Collect Time:* 10:13
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05712**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 17

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-17 GB6

*Collect Date:* 04/26/2016
*Collect Time:* 10:13
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05714**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 18

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-18 GB8

*Collect Date:* 04/26/2016
*Collect Time:* 10:15
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.53 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05715**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 20

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-20 GB5

*Collect Date:* 04/26/2016
*Collect Time:* 10:16
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.59 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05716**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 21

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-21 GB5

*Collect Date:* 04/26/2016
*Collect Time:* 10:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.47 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05717**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 22

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-22 Hallway-GB4

*Collect Date:* 04/26/2016
*Collect Time:* 10:10
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.13 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05718**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 23

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-23 Hallway-GB4

*Collect Date:* 04/26/2016
*Collect Time:* 10:10
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.11 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.005 | 0.015 | S+ | mg/l | SM3113B | HSN | 5/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05719**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 24

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-24 Boys Locker

*Collect Date:* 04/26/2016
*Collect Time:* 10:02
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.020 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05720**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 25

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-25 Boys Locker

*Collect Date:* 04/26/2016
*Collect Time:* 10:02
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.37 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.056 | 0.015 | X | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05721**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 26

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-26 Boys Locker

*Collect Date:* 04/26/2016
*Collect Time:* 10:03
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.41 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

## Chatham Central School

**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05723**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 27

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-27 Kitchen Bath

*Collect Date:* 04/26/2016
*Collect Time:* 10:00
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

### Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.46 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05724**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 28

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-28 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 09:53
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.62 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05726**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 29

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-29 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 09:53
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.58 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05727**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 30

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-30 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 09:54
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.40 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05728**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 31

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-31 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 09:54
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.40 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.016 | 0.015 | M+ | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05729**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 32

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-I-32 Kitchen Ice Machine

*Collect Date:* 04/26/2016
*Collect Time:* 09:58
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | <0.02 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05730**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 33

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-33 Band Office

*Collect Date:* 04/26/2016
*Collect Time:* 09:51
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016
**Sample ID:** **AW05731**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 34

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-34 Boys Bath-Gym

*Collect Date:* 04/26/2016
*Collect Time:* 09:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.24 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | MN | 5/18/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05732**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 35

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-35 Boys Bath-Gym

*Collect Date:* 04/26/2016
*Collect Time:* 09:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.028 | 0.015 | X | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05733**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 36

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-36 Girls Bath-Gym

*Collect Date:* 04/26/2016
*Collect Time:* 09:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.020 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05734**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 37

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-37 Girls Bath-Gym

*Collect Date:* 04/26/2016
*Collect Time:* 09:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.024 | 0.015 | X | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1
**Sample ID:** **AW05735**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 38

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-38 Custodial Office

*Collect Date:* 04/26/2016
*Collect Time:* 10:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.58 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05737**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 39

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-39 Custodial Office

*Collect Date:* 04/26/2016
*Collect Time:* 10:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.59 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016

**Sample ID:** **AW05738**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 40

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-40 Hallway-Gym

*Collect Date:* 04/26/2016
*Collect Time:* 09:48
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.39 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05739**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 41

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-41 Bathroom-Library

*Collect Date:* 04/26/2016
*Collect Time:* 10:05
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.011 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 

**Sample ID:** **AW05740**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 42

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-42 Copy-Library

*Collect Date:* 04/26/2016
*Collect Time:* 10:04
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.38 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05741**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 43

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-43 1A1

*Collect Date:* 04/26/2016
*Collect Time:* 10:21
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.42 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.016 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05742**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 44

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-44 1A1

*Collect Date:* 04/26/2016
*Collect Time:* 10:22
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.42 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.025 | 0.015 | X | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05743**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 46

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-46 1B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.37 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05744**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 47

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-47 1B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

## Chatham Central School

**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 Page 1 of 1

**Sample ID:** **AW05745**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 48

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-48 1B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

### Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.45 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.028 | 0.015 | X | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/7/2016 

**Sample ID:** **AW05746**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/07/2016
*PO Number:*
*Your Ref:* Lab Sample 49

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-49 1B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:34
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.024 | 0.015 | | mg/l | SM3113B | MN | 5/20/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05747**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 50

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-50 1B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:34
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.45 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.034 | 0.015 | X | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05748**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 54

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-54 1B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.96 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.14 | 0.015 | X | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05749**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 55

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-55 1B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.033 | 0.015 | X | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05750**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 56

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-56 1B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.37 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05751**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 57

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-57 1B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.63 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.050 | 0.015 | X | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05752**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 58

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-58 1B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.44 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05753**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 59

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-59 Hallway-1B4

*Collect Date:* 04/26/2016
*Collect Time:* 10:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.017 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05754**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 60

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-60 Hallway-1B4

*Collect Date:* 04/26/2016
*Collect Time:* 10:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.11 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.020 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05755**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 61

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-61 Main Office

*Collect Date:* 04/26/2016
*Collect Time:* 10:08
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.37 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05756**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 62

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-62 1C1

*Collect Date:* 04/26/2016
*Collect Time:* 10:13
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.37 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.015 | 0.015 | M+ | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05757**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 63

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-63 1C7 Nurse

*Collect Date:* 04/26/2016
*Collect Time:* 10:09
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.44 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05758**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 64

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-64 1C7 Nurse

*Collect Date:* 04/26/2016
*Collect Time:* 10:09
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.47 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05759**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 65

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-NI-65 1C7 Nurse

*Collect Date:* 04/26/2016
*Collect Time:* 10:11
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | <0.02 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016
**Sample ID:** **AW05760**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 66

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-66 Hallway-1C7

*Collect Date:* 04/26/2016
*Collect Time:* 10:12
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.60 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05761**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 67

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-67 Hallway-1C7

*Collect Date:* 04/26/2016
*Collect Time:* 10:12
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05762**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 69

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-69 Girls Locker

*Collect Date:* 04/26/2016
*Collect Time:* 10:05
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.56 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.048 | 0.015 | X | mg/l | SM3113B | MN | 5/23/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016

**Sample ID:** **AW05763**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 70

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-70 Girls Locker

*Collect Date:* 04/26/2016
*Collect Time:* 10:05
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05764**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 71

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F71 Girls Locker

*Collect Date:* 04/26/2016
*Collect Time:* 10:05
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.43 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.034 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016

**Sample ID:** **AW05765**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 72

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-72 Faculty

*Collect Date:* 04/26/2016
*Collect Time:* 10:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.13 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05766**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 73

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-73 2A2

*Collect Date:* 04/26/2016
*Collect Time:* 10:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05767**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 74

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-74 2A2

*Collect Date:* 04/26/2016
*Collect Time:* 10:29
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.006 | 0.015 | M+ | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05768**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 75

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-75 2A1

*Collect Date:* 04/26/2016
*Collect Time:* 10:26
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.98 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.027 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05769**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 76

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-76 2A1

*Collect Date:* 04/26/2016
*Collect Time:* 10:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.95 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.027 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05770**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 77

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-77 2A1

*Collect Date:* 04/26/2016
*Collect Time:* 10:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.43 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.006 | 0.015 | M+ | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016

**Sample ID:** **AW05771**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 78

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-78 2A1

*Collect Date:* 04/26/2016
*Collect Time:* 10:29
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.52 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.008 | 0.015 | M+ | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05772**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 79

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-79 Mens-Faculty

*Collect Date:* 04/26/2016
*Collect Time:* 10:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.075 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05773**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 80

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-80 Womens-Faculty

*Collect Date:* 04/26/2016
*Collect Time:* 10:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.17 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**New York State DOH E.L.A.P. # 10350**

**Reviewed by Brian Collins**
These results relate to samples as received.

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05774**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 81

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-81 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.48 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.065 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05775**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 82

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-82 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.50 | 1.3 | X | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.14 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05776**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 83

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-83 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.44 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.038 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05777**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 84

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-84 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.70 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.053 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05778**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 85

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-85 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.59 | 1.3 | | mg/L | SM3111B | NSS | 5/10/2016 |
| Lead | 0.030 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05779**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 86

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-86 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.97 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.058 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05780**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 87

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-87 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.40 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.034 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05781**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 88

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-88 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.51 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.048 | 0.015 | M+X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05782**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 89

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-89 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.024 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016
**Sample ID:** **AW05783**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 90

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-90 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.63 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.045 | 0.015 | M+X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05784**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 91

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-91 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.45 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.029 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05785**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 92

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-92 2B2

*Collect Date:* 04/26/2016
*Collect Time:* 10:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.51 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.064 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05786**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 95

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-95 hallway-2B4

*Collect Date:* 04/26/2016
*Collect Time:* 10:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.17 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05787**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 96

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-96 hallway-2B4

*Collect Date:* 04/26/2016
*Collect Time:* 10:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05788**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 97

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-97 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.046 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05789**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 98

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-98 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.42 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.048 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05790**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 99

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-99 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:25
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.57 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.086 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05792**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 100

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-100 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:25
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.66 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.053 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05794**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 101

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-101 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.36 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.042 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016

**Sample ID:** **AW05795**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 102

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-102 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.041 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05796**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 103

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-103 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:26
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.62 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.066 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05797**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 104

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-104 2B8

*Collect Date:* 04/26/2016
*Collect Time:* 10:26
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.98 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.056 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05798**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 105

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-105 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 4.81 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.087 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05799**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 106

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-106 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 8.14 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.12 | 0.015 | M-X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205



**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016

**Sample ID:** **AW05800**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 107

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-107 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.95 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.040 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05801**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 108

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-108 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.65 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.041 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05802**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 109

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-109 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:18
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.42 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | MN | 5/24/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05803**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 110

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-110 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:18
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.02 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.11 | 0.015 | M+X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05804**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 111

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-111 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:18
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 2.78 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.040 | 0.015 | M+X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05805**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 112

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-112 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:18
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 2.34 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.084 | 0.015 | M+X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 

**Sample ID:** **AW05806**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 113

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-113 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.09 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.052 | 0.015 | X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05807**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 114

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-114 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 3.84 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.15 | 0.015 | M+X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/9/2016 Page 1 of 1

**Sample ID:** **AW05808**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/08/2016
*PO Number:*
*Your Ref:* Lab Sample 115

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-115 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.40 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.040 | 0.015 | M+X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05809**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 116

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-116 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.35 | 1.3 | X | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.25 | 0.015 | M+X | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05810**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 117

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-117 2C3

*Collect Date:* 04/26/2016
*Collect Time:* 10:21
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.19 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.060 | 0.015 | X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05811**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 118

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-F-118 2C6

*Collect Date:* 04/26/2016
*Collect Time:* 10:15
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05812**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 119

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-119 Hallway-2C4

*Collect Date:* 04/26/2016
*Collect Time:* 10:22
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.46 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05813**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 120

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave MS Middle School
*Sample Pt:* MS-DW-120 Hallway-2C4

*Collect Date:* 04/26/2016
*Collect Time:* 10:22
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.49 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06147**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 121

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-1C7 Nurse Bath

*Collect Date:* 04/26/2016
*Collect Time:* 10:10
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.41 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06148**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 122

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-122 Kitchen Pedal

*Collect Date:* 04/26/2016
*Collect Time:* 09:55
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 1.56 | 1.3 | X | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.050 | 0.015 | M+X | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06149**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 123

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-123 Art

*Collect Date:* 04/26/2016
*Collect Time:* 10:23
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06150**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 124

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-124 Art

*Collect Date:* 04/26/2016
*Collect Time:* 10:23
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06151**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 125

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-125 Art

*Collect Date:* 04/26/2016
*Collect Time:* 10:23
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.44 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW06152**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 126

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-126 Art

*Collect Date:* 04/26/2016
*Collect Time:* 10:24
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.59 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06153**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 127

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-127 Art

*Collect Date:* 04/26/2016
*Collect Time:* 10:24
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.44 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06154**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 128

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-128 Art

*Collect Date:* 04/26/2016
*Collect Time:* 10:25
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.42 | 1.3 | | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW06155**
*Date Received:* 05/02/2016
*Time Received:* 15:31
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 129

*Customer:* Chatham Central School
*Owner:* Chatham Middle School
*Sample Loc:* 50 Woodbridge Ave
*Sample Pt:* MS-F-129 2B2-F

*Collect Date:* 04/26/2016
*Collect Time:* 10:37
*Collected by:* B. COLLINS - A. RIZZO
*Receipt Temp:* 22 C see note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 2.30 | 1.3 | X | mg/L | SM3111B | NSS | 5/16/2016 |
| Lead | 0.079 | 0.015 | M+X | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05815**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 1

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-1 room120

*Collect Date:* 04/26/2016
*Collect Time:* 08:12
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.027 | 0.015 | X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05816**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 2

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-2 room120

*Collect Date:* 04/26/2016
*Collect Time:* 08:13
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 5/11/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05817**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 3

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-3 room121

*Collect Date:* 04/26/2016
*Collect Time:* 08:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.039 | 0.015 | X | mg/l | SM3113B | MN | 5/25/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05818**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 4

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-4 room121

*Collect Date:* 04/26/2016
*Collect Time:* 08:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.55 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.045 | 0.015 | M+X | mg/l | SM3113B | MN | 6/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05819**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 5

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-5 room121

*Collect Date:* 04/26/2016
*Collect Time:* 08:18
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.15 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.010 | 0.015 | | mg/l | SM3113B | MN | 5/26/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05820**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 6

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-6 room121

*Collect Date:* 04/26/2016
*Collect Time:* 08:19
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.60 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05822**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 7

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-7 room121

*Collect Date:* 04/26/2016
*Collect Time:* 08:19
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.13 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05823**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 8

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-8 room121

*Collect Date:* 04/26/2016
*Collect Time:* 08:19
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.11 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05824**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 9

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-9 room121

*Collect Date:* 04/26/2016
*Collect Time:* 08:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.10 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.003 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05825**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 10

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-10 room122

*Collect Date:* 04/26/2016
*Collect Time:* 08:22
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.85 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.26 | 0.015 | M+X | mg/l | SM3113B | MN | 6/13/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05826**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 11

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-11 room122

*Collect Date:* 04/26/2016
*Collect Time:* 08:23
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.017 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05827**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 12

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-12 room122

*Collect Date:* 04/26/2016
*Collect Time:* 08:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.018 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05828**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 13

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-13 room123

*Collect Date:* 04/26/2016
*Collect Time:* 08:29
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.073 | 0.015 | X | mg/l | SM3113B | MN | 6/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05829**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 14

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-14 room123

*Collect Date:* 04/26/2016
*Collect Time:* 08:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.54 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.061 | 0.015 | X | mg/l | SM3113B | MN | 6/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05830**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 15

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-15 room123

*Collect Date:* 04/26/2016
*Collect Time:* 08:28
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.032 | 0.015 | M+X | mg/l | SM3113B | MN | 6/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05832**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 16

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-16 124A

*Collect Date:* 04/26/2016
*Collect Time:* 08:34
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.067 | 0.015 | X | mg/l | SM3113B | MN | 6/14/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05833**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 17

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-17 room125

*Collect Date:* 04/26/2016
*Collect Time:* 08:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.10 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05834**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 18

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-18 room125

*Collect Date:* 04/26/2016
*Collect Time:* 08:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | MN | 6/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05835**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 19

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-19 room125

*Collect Date:* 04/26/2016
*Collect Time:* 08:38
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.043 | 0.015 | X | mg/l | SM3113B | MN | 6/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05836**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 20

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-20 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:41
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.037 | 0.015 | M+X | mg/l | SM3113B | MN | 6/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05837**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 21

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-21 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:41
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.017 | 0.015 | M+ | mg/l | SM3113B | MN | 6/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05838**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 22

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-22 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.026 | 0.015 | M+X | mg/l | SM3113B | MN | 6/15/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05840**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 23

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-23 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.019 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05841**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 24

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-24 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.41 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.020 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05843**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 25

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-25 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:43
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05844**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 26

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-26 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:44
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.034 | 0.015 | X | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05845**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 27

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-27 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:44
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05846**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 28

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-28 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:45
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.030 | 0.015 | M+X | mg/l | SM3113B | MN | 5/27/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05847**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 29

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-29 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:45
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.016 | 0.015 | M+ | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05848**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 30

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-30 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:45
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.032 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05849**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 31

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-31 room126

*Collect Date:* 04/26/2016
*Collect Time:* 08:46
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.022 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05850**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 33

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-33 room126A

*Collect Date:* 04/26/2016
*Collect Time:* 08:47
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.39 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.074 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05851**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 34

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-34 room127

*Collect Date:* 04/26/2016
*Collect Time:* 08:51
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.022 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05852**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 35

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-35 room127

*Collect Date:* 04/26/2016
*Collect Time:* 08:52
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.024 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05853**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 36

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-36 room127

*Collect Date:* 04/26/2016
*Collect Time:* 08:52
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.43 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.046 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05854**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 37

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-37 room127

*Collect Date:* 04/26/2016
*Collect Time:* 08:53
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.060 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

Qualifiers Key:
- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved in lab
- S(+/-) Lab control sample outside acceptance limits
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05855**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 38

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-38 Boys Bath-128

*Collect Date:* 04/26/2016
*Collect Time:* 08:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.14 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.021 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05856**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 39

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-39 Boys Bath-128

*Collect Date:* 04/26/2016
*Collect Time:* 08:49
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.016 | 0.015 | | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05857**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 40

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-40 Girls Bath-128

*Collect Date:* 04/26/2016
*Collect Time:* 08:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.17 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.017 | 0.015 | | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05858**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 41

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-41 Girls Bath-128

*Collect Date:* 04/26/2016
*Collect Time:* 08:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.027 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05859**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 42

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-42 Girls Bath-128

*Collect Date:* 04/26/2016
*Collect Time:* 08:50
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.032 | 0.015 | M-X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05860**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 43

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-43 Hallway128-water fountain

*Collect Date:* 04/26/2016
*Collect Time:* 08:48
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.14 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.007 | 0.015 | | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05861**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 45

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-45 Hallway cust.-water fountain

*Collect Date:* 04/26/2016
*Collect Time:* 08:16
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.23 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.043 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05862**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 46

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-46 Hallway cust.-water fountain

*Collect Date:* 04/26/2016
*Collect Time:* 08:16
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.066 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05863**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 47

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-47 Custodian Fountain

*Collect Date:* 04/26/2016
*Collect Time:* 08:15
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.65 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05864**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 48

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-48 Custodian Room

*Collect Date:* 04/26/2016
*Collect Time:* 08:15
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.22 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05866**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 49

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-49 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 08:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.46 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.024 | 0.015 | M-X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05867**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 50

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-50 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 08:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.49 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.024 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05868**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 51

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-51 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 08:40
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.018 | 0.015 | M+ | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05870**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 52

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-52 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 08:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.025 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 

**Sample ID:** **AW05872**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 53

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-53 Kitchen

*Collect Date:* 04/26/2016
*Collect Time:* 08:39
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.031 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05873**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 54

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-54 Faculty

*Collect Date:* 04/26/2016
*Collect Time:* 08:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05874**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 55

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-55 Room 107

*Collect Date:* 04/26/2016
*Collect Time:* 08:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.43 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.052 | 0.015 | X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05875**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 56

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-56 Room 107

*Collect Date:* 04/26/2016
*Collect Time:* 08:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.023 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05876**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 57

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-57 Room 107

*Collect Date:* 04/26/2016
*Collect Time:* 08:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.034 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05877**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 58

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-58 Room 105

*Collect Date:* 04/26/2016
*Collect Time:* 08:34
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.038 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05879**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 59

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-59 Boys Bath 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.33 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.036 | 0.015 | M+X | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05880**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 60

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-60 Boys Bath 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.18 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | MN | 5/31/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05881**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 61

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-61 Boys Bath 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.24 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05882**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 62

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-62 Girls Bath 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.013 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05884**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 63

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-63 Girls Bath 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.32 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05885**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 64

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-64 Girls Bath 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05886**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 65

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-65 Hallway 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05887**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 66

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-66 Hallway 104

*Collect Date:* 04/26/2016
*Collect Time:* 08:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.31 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.004 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05888**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 67

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-67 Library

*Collect Date:* 04/26/2016
*Collect Time:* 08:30
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.47 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.045 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05889**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 68

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-68 Library

*Collect Date:* 04/26/2016
*Collect Time:* 08:29
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.52 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.080 | 0.015 | M+X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05890**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 69

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-69 Main Office

*Collect Date:* 04/26/2016
*Collect Time:* 08:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.38 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.026 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05891**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 70

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-70 Mens Bath Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 08:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.60 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.008 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05892**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 71

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-71 Womens Bath Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 08:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.71 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05893**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 72

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-72 Lobby

*Collect Date:* 04/26/2016
*Collect Time:* 08:24
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/12/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05894**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 73

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-73 Nurse

*Collect Date:* 04/26/2016
*Collect Time:* 08:22
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.60 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.015 | 0.015 | | mg/l | SM3113B | MN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05895**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 74

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-74 Nurse

*Collect Date:* 04/26/2016
*Collect Time:* 08:22
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.45 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.009 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05896**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 75

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-75 Boys Bath Gym Hall

*Collect Date:* 04/26/2016
*Collect Time:* 08:23
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05897**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 76

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-76 Girls Bath Gym Hall

*Collect Date:* 04/26/2016
*Collect Time:* 08:18
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.006 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05898**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 77

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-77 Gym Hall

*Collect Date:* 04/26/2016
*Collect Time:* 08:19
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.12 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05899**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 78

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-78 Gym Hall

*Collect Date:* 04/26/2016
*Collect Time:* 08:19
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.12 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | <0.001 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05900**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 79

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-I-79 Mech RM Ice Machine

*Collect Date:* 04/26/2016
*Collect Time:* 08:21
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.39 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.012 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05903**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 80

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-80 Girls Locker

*Collect Date:* 04/26/2016
*Collect Time:* 08:18
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.21 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.002 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 

**Sample ID:** **AW05904**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 81

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-81 Girls Locker

*Collect Date:* 04/26/2016
*Collect Time:* 08:17
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.51 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.058 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05905**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 82

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-82 Boys Locker

*Collect Date:* 04/26/2016
*Collect Time:* 08:16
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.44 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.011 | 0.015 | | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05906**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 83

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-DW-83 Boys Locker

*Collect Date:* 04/26/2016
*Collect Time:* 08:16
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.026 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05907**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 84

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-84 Room 124

*Collect Date:* 04/26/2016
*Collect Time:* 08:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.30 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.034 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05911**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 85

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-85 Room 124

*Collect Date:* 04/26/2016
*Collect Time:* 08:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.35 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.024 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05912**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 86

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-86 Room 124

*Collect Date:* 04/26/2016
*Collect Time:* 08:32
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.40 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.20 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05914**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*YourRef:* Lab Sample 87

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-87 Room 124

*Collect Date:* 04/26/2016
*Collect Time:* 08:33
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.018 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/13/2016 Page 1 of 1

**Sample ID:** **AW05915**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/13/2016
*PO Number:*
*Your Ref:* Lab Sample 88

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-88 Room 107

*Collect Date:* 04/26/2016
*Collect Time:* 08:35
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.40 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.028 | 0.015 | X | mg/l | SM3113B | HSN | 6/11/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
LEAD: The test result for Lead is above acceptable limits.

Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05916**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 89

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-89 Room 121

*Collect Date:* 04/26/2016
*Collect Time:* 08:20
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.16 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.014 | 0.015 | | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05917**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 90

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-90 Room 123

*Collect Date:* 04/26/2016
*Collect Time:* 08:26
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.19 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.029 | 0.015 | X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05918**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 91

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-91 Room 123

*Collect Date:* 04/26/2016
*Collect Time:* 08:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.028 | 0.015 | X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05919**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 92

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-92 Room 124

*Collect Date:* 04/26/2016
*Collect Time:* 08:31
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.34 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.028 | 0.015 | X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05920**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 93

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-93 Room 124A

*Collect Date:* 04/26/2016
*Collect Time:* 08:34
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.25 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.16 | 0.015 | X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05921**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 94

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-94 Room 125

*Collect Date:* 04/26/2016
*Collect Time:* 08:36
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.27 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.037 | 0.015 | X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05922**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 95

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-95 Room 125

*Collect Date:* 04/26/2016
*Collect Time:* 08:37
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.28 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.032 | 0.015 | X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05923**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 96

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-96 Band Room

*Collect Date:* 04/26/2016
*Collect Time:* 08:14
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.46 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.023 | 0.015 | | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05924**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 97

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-97 Dishwasher

*Collect Date:* 04/26/2016
*Collect Time:* 08:37
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.64 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.005 | 0.015 | | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**


| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05925**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 98

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-98 Mens Fac

*Collect Date:* 04/26/2016
*Collect Time:* 08:42
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.29 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.014 | 0.015 | M- | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05926**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 99

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-99 Womens Fac

*Collect Date:* 04/26/2016
*Collect Time:* 08:43
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.36 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.017 | 0.015 | | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05927**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 100

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-100 Main Office

*Collect Date:* 04/26/2016
*Collect Time:* 08:27
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.61 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.027 | 0.015 | M-X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

(518) 525-5475 **ST. PETER'S HOSPITAL ENVIRONMENTAL LABORATORY** 19 WAREHOUSE ROW ALBANY, NEW YORK 12205

**Chatham Central School**
**50 Woodbridge Ave**

**Chatham ,NY 12037**

**Printed On** 6/17/2016 Page 1 of 1

**Sample ID:** **AW05928**
*Date Received:* 04/26/2016
*Time Received:* 10:03
*Date Finalized:* 06/17/2016
*PO Number:*
*Your Ref:* Lab Sample 101

*Customer:* Chatham Central School
*Owner:* Chatham Central School
*Sample Loc:* 50 Woodbridge Ave HS High School
*Sample Pt:* HS-F-101 123A

*Collect Date:* 04/26/2016
*Collect Time:* 08:58
*Collected by:* B. COLLINS/A. RIZZO
*Receipt Temp:* 22 C See Note 1

*Water Source:*
*Chlorinated:* Yes *Field Residual Chlorine:*

*Potability:* Yes
*Grab/Comp:* Grab

## Laboratory Report

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|---|---|---|---|---|---|---|
| Copper | 0.26 | 1.3 | | mg/L | SM3111B | NSS | 5/13/2016 |
| Lead | 0.053 | 0.015 | X | mg/l | SM3113B | MN | 6/12/2016 |

**Qualifiers Key:**

| | | | | | |
|---|---|---|---|---|---|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| P | Sample preserved in lab | Z | Analysis is not state-certified | C | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | | |

**Legend**: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

***Comments:***
Test procedures for all analyses meet NELAC requirements.

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480/5479

**Reviewed by Brian Collins**
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**