

CLIENT INFORMATION

Name: Chatham Central School District
Address: 50 Woodbridge Ave Chatham, NY 12037
Client Rep: Ethan Stalter

Date of Sampling: 2025
Samples Taken By: Lisa Lyons
Samples Taken By:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Chatham Middle School
BLDG ADDRESS:
CONTACT NAME & NUMBERS: Ethan Stalter (518) 788-6264

SAMPLE DATA

Sample Description ID (ID must match container label)					Outlet Information							
Lab Sample #	MS Sample ID	Level	Location	Outlet Description	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
1	MS-GA-F-L-1	GA	GA 1 Computer/Tech	Sink Left	MS-GA-F-L-1	11/15/2025 6:52	12/1/2025 14:51	25K1939-01	Lead	10	5	ug/L
2	MS-GA-DW-L-2	GA	GA 1 Computer/Tech	Fountain Left	MS-GA-DW-L-2	11/15/2025 6:53	12/1/2025 14:53	25K1939-02	Lead	11.6	5	ug/L
3	MS-GA-F-R-3	GA	GA 1 Computer/Tech	Sink Right	MS-GA-F-R-3	11/15/2025 6:54	12/1/2025 14:56	25K1939-03	Lead	5.13	5	ug/L
4	MS-GA-DW-R-4	GA	GA 1 Computer/Tech	Fountain Right	MS-GA-DW-R-4	11/15/2025 6:55	12/1/2025 14:58	25K1939-04	Lead	4.43	5	ug/L
5	MS-GB-F-5	GB	GB 1 Classroom	Sink	MS-GB-F-5	11/15/2025 6:46	12/1/2025 15:00	25K1939-05	Lead	3.11	5	ug/L
6	MS-GB-DW-6	GB	GB 1 Classroom	Fountain	MS-GB-DW-6	11/15/2025 6:47	12/1/2025 15:03	25K1939-06	Lead	10.1	5	ug/L
7	MS-GB-F-7	GB	GB 2 Classroom	Sink	MS-GB-F-7	11/15/2025 6:48	12/1/2025 15:10	25K1939-07	Lead	5.51	5	ug/L
8	MS-GB-DW-8	GB	GB 2 Classroom	Fountain	MS-GB-DW-8	11/15/2025 6:49	12/1/2025 15:12	25K1939-08	Lead	5.39	5	ug/L
9	MS-GB-DW-L-9	GB	Corridor Outside GB 4	Fountain L	MS-GB-DW-L-9	11/15/2025 6:50	12/1/2025 15:15	25K1939-09	Lead	2.84	5	ug/L
10	MS-GB-DW-R-10	GB	Corridor Outside GB 4	Fountain R	MS-GB-DW-R-10	11/15/2025 6:51	12/1/2025 15:31	25K1939-10	Lead	2.59	5	ug/L
11	MS-GB-F-11	GB	GB 4 Classroom	Sink	MS-GB-F-11	11/15/2025 6:45	12/1/2025 16:10	25K1939-11	Lead	3.33	5	ug/L
12	GB	GB 4	Classroom Fountain	Dry	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
13	MS-GB-F-13	GB	GB 5 Classroom	Sink	MS-GB-F-13	11/15/2025 6:41	12/1/2025 16:13	25K1939-12	Lead	3.95	5	ug/L
14	MS-GB-DW-14	GB	GB 5 Classroom	Fountain	MS-GB-DW-14	11/15/2025 6:42	12/1/2025 16:15	25K1939-13	Lead	2.57	5	ug/L
15	MS-GB-F-15	GB	GB 6 Classroom	Sink	MS-GB-F-15	11/15/2025 6:43	12/1/2025 16:20	25K1939-14	Lead	6.7	5	ug/L
16	MS-GB-DW-16	GB	GB 6 Classroom	Fountain	MS-GB-DW-16	11/15/2025 6:44	12/1/2025 16:20	25K1939-15	Lead	4.44	5	ug/L
17	MS-GB-F-17	GB	GB 7 Classroom	Sink	MS-GB-F-17	11/15/2025 6:39	12/1/2025 16:22	25K1939-16	Lead	4.65	5	ug/L
18	GB	GB 7	Classroom Fountain	Dry	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
19	MS-GC-DW-19	GC	GC 9 Gymnasium	Fountain	MS-GC-DW-19	11/15/2025 7:05	12/1/2025 16:25	25K1939-17	Lead	<2.00	5	ug/L
20	MS-GC-DW-20	GC	GC 5 Cafeteria	Fountain	MS-GC-DW-20	11/15/2025 7:07	12/1/2025 16:27	25K1939-18	Lead	<2.00	5	ug/L
21	MS-GC-DW-BF-	GC	GC 5 Cafeteria	Bottle Filler	MS-GC-DW-BF-21	11/15/2025 7:08	12/1/2025 16:29	25K1939-19	Lead	<2.00	5	ug/L
22	MS-GC-KF-CTR	GC	GC 7 Kitchen Center	Sink	MS-GC-KF-CTR 22	11/15/2025 7:09	12/1/2025 16:32	25K1939-20	Lead	<2.00	5	ug/L
23	MS-GC-KF-23	GC	GC 7 Kitchen L	Sink	MS-GC-KF-23	11/15/2025 7:10	12/1/2025 16:46	25K1939-21	Lead	<2.00	5	ug/L
24	MS-GC-KF-24	GC	GC 7 Kitchen R	Sink	MS-GC-KF-24	11/15/2025 7:11	12/1/2025 16:49	25K1939-22	Lead	<2.00	5	ug/L
25	MS-1A-F-25	1A	Library Prep Room 1A5	Sink	MS-1A-F-25	11/15/2025 7:00	12/1/2025 16:51	25K1939-23	Lead	3.07	5	ug/L
26	MS-1B-DW-L-26	1B	Corridor Outside 1B 4	Fountain Left	MS-1B-DW-L-26	11/15/2025 7:27	12/1/2025 16:53	25K1939-24	Lead	5.82	5	ug/L
27	MS-1B-DW-R-27	1B	Corridor Outside 1B 4	Fountain Right	MS-1B-DW-R-27	11/15/2025 7:28	12/1/2025 16:56	25K1939-25	Lead	8.27	5	ug/L
28	MS-1C-DW-L-28	1C	Next to 1C5	Fountain Left	MS-1C-DW-L-28	11/15/2025 7:15	12/1/2025 16:58	25K1939-26	Lead	<2.00	5	ug/L
29	MS-1C-DW-R-29	1C	Next to 1C5	Fountain Right	MS-1C-DW-R-29	11/15/2025 7:16	12/1/2025 17:01	25K1939-27	Lead	<2.00	5	ug/L
30	MS-1C-DW-BF-30	1C	Next to 1C5	Bottle Filler	MS-1C-DW-BF-30	11/15/2025 7:17	12/1/2025 17:03	25K1939-28	Lead	<2.00	5	ug/L
31	MS-1C-DW-31	1C	1C17 Girls Locker Room	Fountain	MS-1C-DW-31	11/15/2025 7:21	12/1/2025 17:25	25K1939-29	Lead	<2.00	5	ug/L
32	1C	1C17	Girls Locker Room Bottle Filler	Dry	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
33	MS-2A-F-33	2A	2A 3 Faculty	Sink	MS-2A-F-33	11/15/2025 7:31	12/1/2025 17:27	25K1939-30	Lead	18.9	5	ug/L
34	MS-2A-F-34	2A	2A 1 FACS Sink 1	Sink	MS-2A-F-34	11/15/2025 7:35	12/1/2025 17:29	25K1939-31	Lead	3.27	5	ug/L
35	MS-2A-F-35	2A	2A 1 FACS Sink 2	Sink	MS-2A-F-35	11/15/2025 7:36	12/1/2025 17:32	25K1939-32	Lead	4.08	5	ug/L
36	MS-2A-F-36	2A	2A 1 FACS Sink 3	Sink	MS-2A-F-36	11/15/2025 7:37	12/1/2025 17:34	25K1939-33	Lead	2.23	5	ug/L
37	MS-2A-F-37	2A	2A 1 FACS Sink 4	Sink	MS-2A-F-37	11/15/2025 7:38	12/1/2025 17:36	25K1939-34	Lead	<2.00	5	ug/L
38	MS-2B-DW-L-38	2B	Corridor Outside 2B 4	Fountain Left	MS-2B-DW-L-38	11/15/2025 7:39	12/1/2025 17:43	25K1939-35	Lead	4.69	5	ug/L
39	MS-2B-DW-R-39	2B	Corridor Outside 2B 4	Fountain Right	MS-2B-DW-R-39	11/15/2025 7:40	12/1/2025 17:46	25K1939-36	Lead	4.62	5	ug/L

Lab Sample #	MS Sample ID	Level	Location	Outlet Description	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
40	MS-2C-DW-L-40	2C	Corridor Outside 2C4	Fountain Left	MS-2C-DW-L-40	11/15/2025 7:26	12/1/2025 17:48	25K1939-37	Lead	<2.00	5	ug/L
41	MS-2C-DW-R-41	2C	Corridor Outside 2C4	Fountain Right	MS-2C-DW-R-41	11/15/2025 7:24	12/1/2025 17:51	25K1939-38	Lead	<2.00	5	ug/L