

School District of Denmark
Questions and Responses
INVITATION TO BID (ITB) FOOD SERVICE EQUIPMENT

August 10, 2023

1. The specification for Denmark Elementary School has FEC hanging the hood and installing the wall cladding and HVAC providing and installing all ductwork and fire suppression. Can you please clarify that HVAC is in fact providing and installing the fire suppression? I want to make sure we are not including the fire suppression in our proposal if it is being picked up by a different trade.

HVAC is excluded from this ITB as noted on page 20 of the general conditions. Section Z Work Excluded includes the fire suppression system. The fire suppression system should be excluded from the proposal