



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Delaware-Chenango-Madison-Otsego BOCES

Project Name: Pole Campus - Norwich

Harrold Studer  
6678 COUNTY ROAD 32  
Norwich, NY 13815

Project / PO Number: 26-02306  
Received: 11/24/2025  
Reported: 01/12/2026

Analytical Testing Parameters

Client Sample ID: 100 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-01

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1223 | JDF     |

Client Sample ID: 100 - S1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-02

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | 0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1228 | JDF     |

Client Sample ID: 100 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-03

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1230 | JDF     |

Client Sample ID: 103 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-04

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1232 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 103 - S3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-05

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0021 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1234 | JDF     |

Client Sample ID: 103 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-06

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1236 | JDF     |

Client Sample ID: 103 - 10 - SP1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-07

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1241 | JDF     |

Client Sample ID: 103 - 10 - SP2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-08

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1243 | JDF     |

Client Sample ID: 103 - 10 - SP3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-09

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1245 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 105 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-10

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1247 | JDF     |

Client Sample ID: 105 - S12  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-11

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1248 | JDF     |

Client Sample ID: 105 - S7  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-12

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1252 | JDF     |

Client Sample ID: 105 - S8  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-13

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1254 | JDF     |

Client Sample ID: 105 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-14

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1256 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 106 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-15

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1258 | JDF     |

Client Sample ID: 106 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-16

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1303 | JDF     |

Client Sample ID: 107.2 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-17

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0012 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1305 | JDF     |

Client Sample ID: 109.5 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-18

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1307 | JDF     |

Client Sample ID: 112.5 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-19

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1309 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 116 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-20

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1639 | 01/08/26 1310 | JDF     |

Client Sample ID: 121 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-21

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1558 | JDF     |

Client Sample ID: 123 - ICE  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-22

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1603 | JDF     |

Client Sample ID: 123 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-23

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1605 | JDF     |

Client Sample ID: 123 - S3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-24

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0015 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1607 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 123 - S4  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-25

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0011 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1609 | JDF     |

Client Sample ID: 123 - S5  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-26

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1611 | JDF     |

Client Sample ID: 123 - S8  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-27

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0016 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1616 | JDF     |

Client Sample ID: 123 - S9  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-28

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0037 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1618 | JDF     |

Client Sample ID: 123 - SP1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-29

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:53

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0043 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1620 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 123 - SP2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-30

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0843 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1622 | JDF     |

Client Sample ID: 123 - SP3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-31

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0621 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1623 | JDF     |

Client Sample ID: 123.1 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-32

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0024 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1627 | JDF     |

Client Sample ID: 123.6 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-33

Collected By: Harrold Studer  
Collection Date: 11/22/2025 5:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0043 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1629 | JDF     |

Client Sample ID: 126 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-34

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0015 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1631 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 129 - CM  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-35

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0024 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1633 | JDF     |

Client Sample ID: 138 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-36

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1638 | JDF     |

Client Sample ID: 139 - S3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-37

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1640 | JDF     |

Client Sample ID: 139 - S4  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-38

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1642 | JDF     |

Client Sample ID: 139 - S5  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-39

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1644 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 140 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-40

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1550 | 01/07/26 1645 | JDF     |

Client Sample ID: 149 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-41

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1804 | JDF     |

Client Sample ID: 150.2 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-42

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0043 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1810 | JDF     |

Client Sample ID: 151 - S1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-43

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1811 | JDF     |

Client Sample ID: 151 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-44

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1813 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 153 - S1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-45

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0017 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1815 | JDF     |

Client Sample ID: 153 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-46

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0097 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1817 | JDF     |

Client Sample ID: 154 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-47

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0019 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1822 | JDF     |

Client Sample ID: 156.1 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-48

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0015 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1824 | JDF     |

Client Sample ID: 159 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-49

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0021 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1826 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 160 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-50

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1828 | JDF     |

Client Sample ID: 161 - S1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-51

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1830 | JDF     |

Client Sample ID: 161 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-52

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1833 | JDF     |

Client Sample ID: 162 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-53

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1835 | JDF     |

Client Sample ID: 164 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-54

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1837 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 167 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-55

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1839 | JDF     |

Client Sample ID: 168 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-56

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1844 | JDF     |

Client Sample ID: 169 - S1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-57

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1846 | JDF     |

Client Sample ID: 169 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-58

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1848 | JDF     |

Client Sample ID: 169.1 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-60

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0185 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1850 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: 170 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-61

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1622 | 01/07/26 1852 | JDF     |

Client Sample ID: 171 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-62

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2319 | JDF     |

Client Sample ID: 172 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-63

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2325 | JDF     |

Client Sample ID: C1 - 10 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-64

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2327 | JDF     |

Client Sample ID: C1 - 10 - HF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-65

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2329 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: C1 - 10 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-66

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2330 | JDF     |

Client Sample ID: C1 - 10.2 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-67

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2332 | JDF     |

Client Sample ID: C1 - 10.2 - HF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-68

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2338 | JDF     |

Client Sample ID: C1 10.2 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-69

Collected By: Harrold Studer  
Collection Date: 11/22/2025 6:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2340 | JDF     |

Client Sample ID: C1 - 13 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-70

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2341 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: C1 - 13 - HF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-71

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2343 | JDF     |

Client Sample ID: C1 - 13 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-72

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2345 | JDF     |

Client Sample ID: C1 - 17 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-73

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2349 | JDF     |

Client Sample ID: C1 - 17 - HF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-74

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2351 | JDF     |

Client Sample ID: C1 - 17 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-75

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2353 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: C1 - 3 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-76

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/07/26 2354 | JDF     |

Client Sample ID: C1 - 7 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-77

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/08/26 0000 | JDF     |

Client Sample ID: CG - 1 - BF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-78

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/08/26 0002 | JDF     |

Client Sample ID: CG - 1 - HF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-79

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/08/26 0004 | JDF     |

Client Sample ID: CG - 1 - WF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-80

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/08/26 0005 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: G02 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-81

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1735 | 01/08/26 0007 | JDF     |

Client Sample ID: G04 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-82

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0022 | JDF     |

Client Sample ID: G06 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-83

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0024 | JDF     |

Client Sample ID: G08 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-84

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0026 | JDF     |

Client Sample ID: G10 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-85

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:22

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0028 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: G11.4 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-86

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0029 | JDF     |

Client Sample ID: G12 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-87

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0018 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0035 | JDF     |

Client Sample ID: G13 - S2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-89

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0017 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0037 | JDF     |

Client Sample ID: G13 - S3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-90

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0039 | JDF     |

Client Sample ID: G13 - S4  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-91

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0041 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: G13.1 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-92

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0059 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0046 | JDF     |

Client Sample ID: G14 - S3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-95

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0016 | JDF     |

Client Sample ID: G15 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-96

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0048 | JDF     |

Client Sample ID: SSC - WF1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-97

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0050 | JDF     |

Client Sample ID: SSC - WF2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-98

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0052 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

Client Sample ID: SSC 105 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-99

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0057 | JDF     |

Client Sample ID: SSC 113 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-AA

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0059 | JDF     |

Client Sample ID: SSC 129 - S  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-AB

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:53

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0101 | JDF     |

Client Sample ID: SSC 129 - ICE  
Sample Matrix: Drinking Water  
Lab Sample ID: J5K0914-AC

Collected By: Harrold Studer  
Collection Date: 11/22/2025 7:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/07/26 1736 | 01/08/26 0042 | JDF     |

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level  
MCL: US EPA Maximum Contaminant Level  
mg/L: Milligrams per Liter  
RL: Reporting Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0914

**Project Requested Certification(s)**

Microbac Laboratories, Inc. - Dayville

11549

Microbac Laboratories, Inc., New York Division

68-01385

New York State Department of Health

Pennsylvania Department of Environmental Protection

---

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

**Reviewed and Approved By:**

Shannon Weeks

Operations Manager

Reported: 01/12/2026 10:12

## CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID IR-2

Holding Time

Samples Received on Ice? ☒ Yes ☒ No ☐ N/ACustody Seals Intact? ☒ Yes ☐ No ☐ N/A

## Lab Report Address

Client Name: DCMO BOCES

Address: 6678 Co Rd. 32

City, State, Zip: NORWICH, NY 13815

Contact: HAROLD STUDER

Telephone No.: 1-607-335-1291

## Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

## Turnaround Time

☐ Routine (5 to 7 business days)☐ RUSH\* (notify lab)

(needed by)

## Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Report via:

☒ Mail☐ Fax☒ e-mail (address)

HAROLD.STUDER@DCMOBOCES.COM

Send Invoice via:

☒ Mail☐ Fax☐ e-mail (address)

Project: POLE CAMPUS

Location: NORWICH

PO No.: 26-02306

Compliance Monitoring? ☐ Yes ☐ No☐ Agency/Program

Sampled by (PRINT):

HAROLD STUDER

Sampler Signature:

Sampler Phone No.:

1-607-335-1291

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

RLF 11/24/25

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** | LEAD |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|------|
| 001    | 100-BF           | 11-22-25       | 0501           | 1                 | DW     | G           | U                     |      |
| 002    | 100-S1           |                | 0503           |                   |        |             |                       |      |
| 003    | 100-WF           |                | 0501           |                   |        |             |                       |      |
| 004    | 103-BF           |                | 0505           |                   |        |             |                       |      |
| 005    | 103-S3           |                | 0506           |                   |        |             |                       |      |
| 006    | 103-WF           |                | 0505           |                   |        |             |                       |      |
| 007    | 103.10-SP1       |                | 0512           |                   |        |             |                       |      |
| 008    | 103.10-SP2       |                | 0513           |                   |        |             |                       |      |
| 009    | 103.10-SP3       |                | 0514           |                   |        |             |                       |      |
| 010    | 105-BF           |                | 0520           |                   |        |             |                       |      |

Possible Hazard Identification  
Comments☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition

☐ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Relinquished By (signature)

Date/Time

11/24/25 8:22 am

Date/Time

Received By (signature)

Received By (signature)

Date/Time

11/24/25 08:22

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

HNO3 ADDED TO SAMPLES - J547017 - RLF 12/09/25

rev. 7/18/18

Page 1 of 11

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Lab Report Address

Client Name: *DCMO BOCES*

Address: *6678 Co Rd. 32*

City, State, Zip: *NORWICH, NY 13815*

Contact: *HAROLD STUDER*

Telephone No.: *1-607-335-1291*

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Report via:

☐ Mail

☐ Fax

☒ e-mail (address) *HAROLD\_STUDER@DCMOBOCES.COM*

Send Invoice via:

☐ Mail

☐ Fax

☐ e-mail (address)

Project: *POLE CAMPUS*

Location: *NORWICH*

PO No.: *26-02306*

Compliance Monitoring? ☐ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT):

*HAROLD STUDER*

Sampler Signature:

*[Signature]*

Sampler Phone No.: *1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 011    | 105-S12          | 11-22-25       | 0523           | 1                 | DW     | G           | U                     |
| 012    | 105-S7           |                | 0523           |                   |        |             |                       |
| 013    | 105-S8           |                | 0524           |                   |        |             |                       |
| 014    | 105-WF           |                | 0520           |                   |        |             |                       |
| 015    | 106-BF           |                | 0528           |                   |        |             |                       |
| 016    | 106-WF           |                | 0528           |                   |        |             |                       |
| 017    | 107.2-S2         |                | 0531           |                   |        |             |                       |
| 018    | 109.5-S          |                | 0534           |                   |        |             |                       |
| 019    | 112.5-S          |                | 0536           |                   |        |             |                       |
| 020    | 116-WF           |                | 0538           |                   |        |             |                       |

DCMO BOCES  
PM: Shannon Weeks



Possible Hazard Identification

☒ Hazardous

☐ Non-Hazardous

☐ Radioactive

Sample Disposition

☐ Dispose as appropriate

☐ Return

☐ Archive

Comments

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Lab Report Address

Client Name: *DCMO BOCES*

Address: *6678 Co Rd. 32*

City, State, Zip: *NORWICH, NY 13815*

Contact: *HAROLD STUDER*

Telephone No.: *1-607-335-1291*

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Report via:

☐ Mail

☐ Fax

☒ e-mail (address)

*HAROLD STUDER@DCMOBOCES.COM*

Send Invoice via:

☐ Mail

☐ Fax

☐ e-mail (address)

Project: *POLE CAMPUS*

Location: *NORWICH*

PO No.: *26-02306*

Compliance Monitoring? ☐ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT):

*HAROLD STUDER*

Sampler Signature:

*[Signature]*

Sampler Phone No.:

*1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO<sub>3</sub>, (2) H<sub>2</sub>SO<sub>4</sub>, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 021    | 121-S            | 11-22-25       | 0541           | 1                 | DW     | G           | U                     |
| 022    | 123-ICE          |                | 0543           |                   |        |             |                       |
| 023    | 123-S2           |                | 0545           |                   |        |             |                       |
| 024    | 123-S3           |                | 0546           |                   |        |             |                       |
| 025    | 123-S4           |                | 0547           |                   |        |             |                       |
| 026    | 123-S5           |                | 0548           |                   |        |             |                       |
| 027    | 123-S8           |                | 0549           |                   |        |             |                       |
| 028    | 123-S9           |                | 0549           |                   |        |             |                       |
| 029    | 123-SPI          |                | 0553           |                   |        |             |                       |
| 030    | 123-SPI2         |                | 0555           |                   |        |             |                       |

Possible Hazard Identification  
Comments

☐ Hazardous

☐ Non-Hazardous

☐ Radioactive

Sample Disposition

☐ Dispose as appropriate

☐ Return

☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time



# CHAIN OF CUSTODY RECORD

Number  
Instructions on back

|                                                                                                                                                                     |                                                                                                                        |                                                                                                                                                                                                                   |                                                                                                                |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|
| Lab Report Address                                                                                                                                                  | Invoice Address                                                                                                        | Turnaround Time                                                                                                                                                                                                   | TO BE COMPLETED BY MICROBAC                                                                                    |
| Client Name: <u>DCMO Boces</u>                                                                                                                                      | Client Name:                                                                                                           | <input type="checkbox"/> Routine (5 to 7 business days)                                                                                                                                                           | Temperature Upon Receipt (°C)                                                                                  |
| Address: <u>6678 Co Rd. 32</u>                                                                                                                                      | Address:                                                                                                               | <input type="checkbox"/> RUSH* (notify lab)                                                                                                                                                                       | Therm ID                                                                                                       |
| City, State, Zip: <u>NORWICH, NY 13815</u>                                                                                                                          | City, State, Zip:                                                                                                      | (needed by)                                                                                                                                                                                                       | Holding Time                                                                                                   |
| Contact: <u>HAROLD STUDER</u>                                                                                                                                       | Contact:                                                                                                               | Report Type                                                                                                                                                                                                       | Samples Received on Ice? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| Telephone No.: <u>1-607-335-1291</u>                                                                                                                                | Telephone No.:                                                                                                         | <input checked="" type="checkbox"/> Results Only <input type="checkbox"/> Level 1 <input type="checkbox"/> Level 2 <input type="checkbox"/> Level 3 <input type="checkbox"/> Level 4 <input type="checkbox"/> EDD | Custody Seals Intact? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A    |
| Send Report via: <input type="checkbox"/> Mail <input type="checkbox"/> Fax <input checked="" type="checkbox"/> e-mail (address) <u>HAROLD.STUDER@DCMOBACES.COM</u> | Send Invoice via: <input type="checkbox"/> Mail <input type="checkbox"/> Fax <input type="checkbox"/> e-mail (address) |                                                                                                                                                                                                                   |                                                                                                                |
| Project: <u>POLE CAMPUS</u>                                                                                                                                         | Location: <u>NORWICH</u>                                                                                               | PO No.: <u>26-02306</u>                                                                                                                                                                                           | Compliance Monitoring? <input type="checkbox"/> Yes <input type="checkbox"/> No                                |
| Sampled by (PRINT): <u>HAROLD STUDER</u>                                                                                                                            | Sampler Signature: <u>[Signature]</u>                                                                                  | Sampler Phone No.: <u>1-607-335-1291</u>                                                                                                                                                                          | <input type="checkbox"/> Agency/Program                                                                        |

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 031    | 123-SP3          | 11-22-25       | 0557           | 2                 | DW     | G           | U                     |
| 032    | 123.1-S2         |                | 0558           |                   |        |             |                       |
| 033    | 123.6-S          |                | 0559           |                   |        |             |                       |
| 034    | 126-S            |                | 0602           |                   |        |             |                       |
| 035    | 129-CM           |                | 0603           |                   |        |             |                       |
| 036    | 138-S            |                | 0609           |                   |        |             |                       |
| 037    | 139-S3           |                | 0610           |                   |        |             |                       |
| 038    | 139-S4           |                | 0610           |                   |        |             |                       |
| 039    | 139-S5           |                | 0610           |                   |        |             |                       |
| 040    | 140-S            |                | 0612           |                   |        |             |                       |



Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive Sample Disposition ☐ Dispose as appropriate ☐ Return ☐ Archive

|          |                             |           |                         |           |
|----------|-----------------------------|-----------|-------------------------|-----------|
| Comments | Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
|          | Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
|          | Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |

# CHAIN OF CUSTODY RECORD

Number  
Instructions on back

Lab Report Address  
Client Name: *DCMO Bocces*  
Address: *6678 Co Rd. 32*  
City, State, Zip: *NORWICH, NY 13815*  
Contact: *HAROLD STUDER*  
Telephone No.: *1-607-335-1291*  
Send Report via: ☒ Mail ☐ Fax ☒ e-mail (address) *HAROLD.STUDER@DCMOBACES.COM*

Invoice Address  
Client Name:  
Address:  
City, State, Zip:  
Contact:  
Telephone No.:

Turnaround Time  
☐ Routine (5 to 7 business days)  
☐ RUSH\* (notify lab)  
(needed by)  
Report Type  
☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD  
Send Invoice via: ☐ Mail ☐ Fax ☐ e-mail (address)

TO BE COMPLETED BY MICROBAC  
Temperature Upon Receipt (°C)  
Therm ID  
Holding Time  
Samples Received on Ice? ☐ Yes ☐ No ☐ N/A  
Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Project: *POLE CAMPUS* Location: *NORWICH*  
Sampled by (PRINT): *HAROLD STUDER* Sampler Signature: *[Signature]*


PO No.: *26-02306* Compliance Monitoring? ☐ Yes ☐ No  
☐ Agency/Program  
Sampler Phone No.: *1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 041    | 149-S            | 11-22-25       | 0615           | 1                 | DW     | G           | U                     |
| 042    | 150.2-S          |                | 0616           |                   |        |             |                       |
| 043    | 151-S1           |                | 0619           |                   |        |             |                       |
| 044    | 157-S2           |                | 0619           |                   |        |             |                       |
| 045    | 153-S1           |                | 0620           |                   |        |             |                       |
| 046    | 153-S2           |                | 0620           |                   |        |             |                       |
| 047    | 154-S            |                | 0625           |                   |        |             |                       |
| 048    | 156.1-S          |                | 0628           |                   |        |             |                       |
| 049    | 159-S            |                | 0629           |                   |        |             |                       |
| 050    | 160-S            |                | 0631           |                   |        |             |                       |



Possible Hazard Identification ☒ Hazardous ☐ Non-Hazardous ☐ Radioactive  
Comments

Sample Disposition ☐ Dispose as appropriate ☐ Return ☐ Archive

|                             |           |                         |           |
|-----------------------------|-----------|-------------------------|-----------|
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |

# CHAIN OF CUSTODY RECORD

Number  
Instructions on back

Lab Report Address  
Client Name: *DCMO BOCES*  
Address: *6678 Co Rd. 32*  
City, State, Zip: *NORWICH, NY 13815*  
Contact: *HAROLD STUDER*  
Telephone No.: *1-607-335-1291*  
Send Report via: ☒ Mail ☐ Fax ☒ e-mail (address) *HAROLD.STUDER@DCMOBOCES.COM*

Invoice Address  
Client Name:  
Address:  
City, State, Zip:  
Contact:  
Telephone No.:

Turnaround Time  
☐ Routine (5 to 7 business days)  
☐ RUSH\* (notify lab)  
  
(needed by)  
Report Type  
☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD  
Send Invoice via: ☐ Mail ☐ Fax ☐ e-mail (address)

TO BE COMPLETED BY MICROBAC  
Temperature Upon Receipt (°C)  
Therm ID  
Holding Time  
Samples Received on Ice? ☐ Yes ☐ No ☐ N/A  
Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Project: *POLE CAMPUS* Location: *NORWICH*

PO No.: *26-02306*

Compliance Monitoring? ☐ Yes ☐ No  
☐ Agency/Program

Sampled by (PRINT): *HAROLD STUDER*

Sampler Signature: *[Signature]*

Sampler Phone No.: *1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 051    | 161-S1           | 11-22-25       | 0634           | 1                 | DW     | G           | 4                     |
| 052    | 161-S2           |                | 0634           |                   |        |             |                       |
| 053    | 162-S            |                | 0636           |                   |        |             |                       |
| 054    | 164-S            |                | 0638           |                   |        |             |                       |
| 055    | 167-S            |                | 0639           |                   |        |             |                       |
| 056    | 168-S            |                | 0640           |                   |        |             |                       |
| 057    | 169-S1           |                | 0641           |                   |        |             |                       |
| 058    | 169-S2           |                | 0642           |                   |        |             |                       |
| 059    | 169-S3           |                | X              |                   |        |             |                       |
| 060    | 169.1-S          |                | 0644           |                   |        |             |                       |

Possible Hazard Identification  
Comments ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☐ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time



*-Disabled / NA*

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Lab Report Address

Client Name: *DCMO BOCES*

Address: *6678 Co Rd. 32*

City, State, Zip: *NORWICH, NY 13815*

Contact: *HAROLD STUDER*

Telephone No.: *1-607-335-1291*

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Report via:

☐ Mail

☐ Fax

☒ e-mail (address) *HAROLD\_STUDER@DCMOBOCES.COM*

Send Invoice via:

☐ Mail

☐ Fax

☐ e-mail (address)

Project: *POLE CAMPUS*

Location: *NORWICH*

PO No.: *26-02306*

Compliance Monitoring? ☐ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT):

*HAROLD STUDER*

Sampler Signature:

*[Signature]*

Sampler Phone No.:

*1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 061    | 170-S            | 11-22-25       | 0647           | 1                 | DW     | G           | U                     |
| 062    | 171-S            |                | 0649           |                   |        |             |                       |
| 063    | 172-S            |                | 0651           |                   |        |             |                       |
| 064    | C1-10-BF         |                | 0655           |                   |        |             |                       |
| 065    | C1-10-HF         |                | 0655           |                   |        |             |                       |
| 066    | C1-10-WF         |                | 0655           |                   |        |             |                       |
| 067    | C1-10.2-BF       |                | 0658           |                   |        |             |                       |
| 068    | C1-10.2-HF       |                | 0658           |                   |        |             |                       |
| 069    | C1-10.2-WF       |                | 0658           |                   |        |             |                       |
| 070    | C1-13-BF         |                | 0705           |                   |        |             |                       |

Possible Hazard Identification

☐ Hazardous

☐ Non-Hazardous

☐ Radioactive

Comments

Sample Disposition

☐ Dispose as appropriate

☐ Return

☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time



# CHAIN OF CUSTODY RECORD

Number  
Instructions on back

|                                                                                                                                                                     |                                                                                                                        |                                                                                                                                                                                                                   |                                                                                                                |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|
| Lab Report Address                                                                                                                                                  | Invoice Address                                                                                                        | Turnaround Time                                                                                                                                                                                                   | TO BE COMPLETED BY MICROBAC                                                                                    |
| Client Name: <i>DCMO BOCES</i>                                                                                                                                      | Client Name:                                                                                                           | <input type="checkbox"/> Routine (5 to 7 business days)                                                                                                                                                           | Temperature Upon Receipt (°C)                                                                                  |
| Address: <i>6678 Co Rd. 32</i>                                                                                                                                      | Address:                                                                                                               | <input type="checkbox"/> RUSH* (notify lab)                                                                                                                                                                       | Therm ID                                                                                                       |
| City, State, Zip: <i>NORWICH, NY 13815</i>                                                                                                                          | City, State, Zip:                                                                                                      | (needed by)                                                                                                                                                                                                       | Holding Time                                                                                                   |
| Contact: <i>HAROLD STUDER</i>                                                                                                                                       | Contact:                                                                                                               | Report Type                                                                                                                                                                                                       | Samples Received on Ice? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| Telephone No.: <i>1-607-335-1291</i>                                                                                                                                | Telephone No.:                                                                                                         | <input checked="" type="checkbox"/> Results Only <input type="checkbox"/> Level 1 <input type="checkbox"/> Level 2 <input type="checkbox"/> Level 3 <input type="checkbox"/> Level 4 <input type="checkbox"/> EDD | Custody Seals Intact? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A    |
| Send Report via: <input type="checkbox"/> Mail <input type="checkbox"/> Fax <input checked="" type="checkbox"/> e-mail (address) <i>HAROLD.STUDER@DCMOBOCES.COM</i> | Send Invoice via: <input type="checkbox"/> Mail <input type="checkbox"/> Fax <input type="checkbox"/> e-mail (address) |                                                                                                                                                                                                                   |                                                                                                                |

Project: *POLE CAMPUS* Location: *NORWICH* PO No.: *26-02306* Compliance Monitoring? ☐ Yes ☐ No  
☐ Agency/Program

Sampled by (PRINT): *HAROLD STUDER* Sampler Signature: *[Signature]* Sampler Phone No.: *1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 071    | CI-13-HF         | 11-22-25       | 0705           | 1                 | DW     | G           | 4                     |
| 072    | CI-13-WF         |                | 0705           |                   |        |             |                       |
| 073    | CI-17-BF         |                | 0710           |                   |        |             |                       |
| 074    | CI-17-HF         |                | 0710           |                   |        |             |                       |
| 075    | CI-17-WF         |                | 0710           |                   |        |             |                       |
| 076    | CI-3-BF          |                | 0702           |                   |        |             |                       |
| 077    | CI-7-BF          |                | 0703           |                   |        |             |                       |
| 078    | CG-1-BF          |                | 0715           |                   |        |             |                       |
| 079    | CG-1-HF          |                | 0715           |                   |        |             |                       |
| 080    | CG-1-WF          |                | 0715           |                   |        |             |                       |

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive Sample Disposition ☐ Dispose as appropriate ☐ Return ☐ Archive

|                             |           |                         |           |
|-----------------------------|-----------|-------------------------|-----------|
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |



# CHAIN OF CUSTODY RECORD

Number  
Instructions on back

Lab Report Address  
Client Name: DCMO Boces  
Address: 6678 Co Rd. 32  
City, State, Zip: NORWICH, NY 13815  
Contact: HAROLD STUDER  
Telephone No.: 1-607-335-1291  
Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address) HAROLD.STUDER@DCMOBOCES.COM

Invoice Address  
Client Name:  
Address:  
City, State, Zip:  
Contact:  
Telephone No.:

Turnaround Time  
☐ Routine (5 to 7 business days)  
☐ RUSH\* (notify lab)  
(needed by)  
Report Type  
☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD  
Send Invoice via: ☐ Mail ☐ Fax ☐ e-mail (address)

TO BE COMPLETED BY MICROBAC  
Temperature Upon Receipt (°C)  
Therm ID  
Holding Time  
Samples Received on Ice? ☐ Yes ☐ No ☐ N/A  
Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Project: POLE CAMPUS Location: NORWICH PO No.: 26-02306 Compliance Monitoring? ☐ Yes ☐ No  
☐ Agency/Program

Sampled by (PRINT): HAROLD STUDER Sampler Signature: [Signature] Sampler Phone No.: 1-607-335-1291

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected  | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|-----------------|-------------------|--------|-------------|-----------------------|
| 081    | G02-S            | 11-22-25       | 0718            | 7                 | DW     | G           | U                     |
| 082    | G04-S            |                | 0719            |                   |        |             |                       |
| 083    | G06-S            |                | 0720            |                   |        |             |                       |
| 084    | G08-S            |                | 0721            |                   |        |             |                       |
| 085    | G10-S            |                | 0722            |                   |        |             |                       |
| 086    | G11-S            |                | 0724            |                   |        |             |                       |
| 087    | G12-S            |                | 0726            |                   |        |             |                       |
| 088    | G13-S1           |                | <del>0728</del> |                   |        |             |                       |
| 089    | G13-S2           |                | 0728            |                   |        |             |                       |
| 090    | G13-S3           |                | 0728            |                   |        |             |                       |

Possible Hazard Identification  
Comments

☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☐ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time



- Drilled / NA

# CHAIN OF CUSTODY RECORD

Number  
Instructions on back

|                                                                                                                                                                     |                                                                                                                        |                                                                                                                                                                                                                   |                                                                                                                |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|
| Lab Report Address                                                                                                                                                  | Invoice Address                                                                                                        | Turnaround Time                                                                                                                                                                                                   | TO BE COMPLETED BY MICROBAC                                                                                    |
| Client Name: <i>DCMO Boces</i>                                                                                                                                      | Client Name:                                                                                                           | <input type="checkbox"/> Routine (5 to 7 business days)                                                                                                                                                           | Temperature Upon Receipt (°C)                                                                                  |
| Address: <i>6678 Co Rd. 32</i>                                                                                                                                      | Address:                                                                                                               | <input type="checkbox"/> RUSH* (notify lab)                                                                                                                                                                       | Therm ID                                                                                                       |
| City, State, Zip: <i>NORWICH, NY 13815</i>                                                                                                                          | City, State, Zip:                                                                                                      | (needed by)                                                                                                                                                                                                       | Holding Time                                                                                                   |
| Contact: <i>HAROLD STUDER</i>                                                                                                                                       | Contact:                                                                                                               | Report Type                                                                                                                                                                                                       | Samples Received on Ice? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| Telephone No.: <i>1-607-335-1291</i>                                                                                                                                | Telephone No.:                                                                                                         | <input checked="" type="checkbox"/> Results Only <input type="checkbox"/> Level 1 <input type="checkbox"/> Level 2 <input type="checkbox"/> Level 3 <input type="checkbox"/> Level 4 <input type="checkbox"/> EDD | Custody Seals Intact? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A    |
| Send Report via: <input type="checkbox"/> Mail <input type="checkbox"/> Fax <input checked="" type="checkbox"/> e-mail (address) <i>HAROLD.STUDER@DCMOBOCES.COM</i> | Send Invoice via: <input type="checkbox"/> Mail <input type="checkbox"/> Fax <input type="checkbox"/> e-mail (address) |                                                                                                                                                                                                                   |                                                                                                                |

Project: *POLE CAMPUS* Location: *NORWICH* PO No.: *26-02306* Compliance Monitoring? ☐ Yes ☐ No  
☐ Agency/Program

Sampled by (PRINT): *HAROLD STUDER* Sampler Signature: *[Signature]* Sampler Phone No.: *1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO<sub>3</sub>, (2) H<sub>2</sub>SO<sub>4</sub>, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 091    | G13-S4           | 11-22-25       | 0730           | 2                 | DW     | G           | U                     |
| 092    | G13-S1-S         |                | 0731           |                   |        |             |                       |
| 093    | G14-S1           |                |                |                   |        |             |                       |
| 094    | G14-S2           |                |                |                   |        |             |                       |
| 095    | G14-S3           |                | 0733           |                   |        |             |                       |
| 096    | G15-S            |                | 0735           |                   |        |             |                       |
| 097    | SSC-WF1          |                | 0748           |                   |        |             |                       |
| 098    | SSC-WF2          |                | 0750           |                   |        |             |                       |
| 099    | SSC105-S         |                | 0751           |                   |        |             |                       |
| 100    | SSC113-S         |                | 0752           |                   |        |             |                       |

AA

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive Sample Disposition ☐ Dispose as appropriate ☐ Return ☐ Archive

|                             |           |                         |           |
|-----------------------------|-----------|-------------------------|-----------|
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |
| Relinquished By (signature) | Date/Time | Received By (signature) | Date/Time |

Additional Not

*Disabled / 1*  
*Disabled / 1*

DCMO Boces  
PM: Shannon Weeks



# CHAIN OF CUSTODY RECORD

Number  
Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)  
Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Lab Report Address

Client Name: *DCMO Boces*

Address: *6678 Co Rd. 32*

City, State, Zip: *NORWICH, NY 13815*

Contact: *HAROLD STUDER*

Telephone No.: *1-607-335-1291*

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Turnaround Time

☐ Routine (5 to 7 business days)  
☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Report via: ☒ Mail ☐ Fax ☒ e-mail (address) *HAROLD.STUDER@DCMOBOCES.COM*

Send Invoice via: ☐ Mail ☐ Fax ☐ e-mail (address)

Project: *POLE CAMPUS*

Location: *NORWICH*

PO No.: *26-02306*

Compliance Monitoring? ☐ Yes ☐ No  
☐ Agency/Program

Sampled by (PRINT): *HAROLD STUDER*

Sampler Signature: *[Signature]*

Sampler Phone No.: *1-607-335-1291*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

AB  
AC

| Lab ID     | Client Sample ID   | Date Collected  | Time Collected | No. of Containers | Matrix   | Grab / Comp | Preservative Types ** |
|------------|--------------------|-----------------|----------------|-------------------|----------|-------------|-----------------------|
| <i>101</i> | <i>SSC 129-S</i>   | <i>11-22-25</i> | <i>0753</i>    | <i>1</i>          | <i>W</i> | <i>G</i>    | <i>U</i>              |
| <i>102</i> | <i>SSC 129-ICE</i> |                 | <i>0754</i>    |                   |          |             |                       |



Possible Hazard Identification  
Comments

☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☐ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

|            |
|------------|
| PO Date    |
| 10/17/2025 |

|                    |
|--------------------|
| Purchase Order No. |
| 26-02306           |

**PURCHASE ORDER**  
Delaware-Chenango-Madison-Otsego BOCES  
6678 County Rd. 32  
Norwich, NY 13815-3554

|                                                                                                                                                                                                                                              |                                                                                                                                                                                                  |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Order To:</b><br><br>MICROBAC - NEW YORK<br>ATTN: ACCOUNTS RECEIVABLE<br>PO BOX 5150<br>CORTLAND, NY 13045-5150<br><br><b>Contact:</b> Shannon Weeks<br>607-753-3403<br>E-Mail: shannon.weeks@microbac.com<br><br>001694<br>KATEY.NICHOLS | <b>Ship To:</b><br><br>Alan D Pole Campus<br>Delaware-Chenango-Madison-Otsego BOCES<br>6678 County Rd. 32<br>Norwich, NY 13815<br><br><b>Attention:</b> Operations & Maintenance<br>607-335-1220 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

| Requestor                 |                                                                                                                                                 | Department                 | Location           | Ordered By |               |
|---------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|--------------------|------------|---------------|
| Director of Facilities II |                                                                                                                                                 | Operations and Maintenance | Alan D Pole Campus | TOM FARGO  |               |
| Order Quantity            | Item Description                                                                                                                                |                            |                    | Unit Cost  | Extended Cost |
| 105.00 EA                 | The PO number must appear on the OUTSIDE of all packages and on all correspondence.<br><br>LEAD ICP-MS EPA 200.8, Rv. 5.4 (1994) DRINKING WATER |                            |                    | 14.2500    | 1,496.25      |



J 5 K 0 9 1 4

DCMO Boces  
PM: Shannon Weeks

| Budget Code           | Percentage | PO Amount | Encumbrance |
|-----------------------|------------|-----------|-------------|
| A-701-8010-400-01-000 | 100.00%    | 1496.25   | 1496.25     |
| TOTAL                 |            | 1496.25   | 1496.25     |

|                      |          |
|----------------------|----------|
| Total                | 1,496.25 |
| Complete             | Partial  |
| Date Order Completed |          |
| Administrator/Date   |          |