



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Delaware-Chenango-Madison-Otsego BOCES

Jason Lawrence  
6678 COUNTY ROAD 32  
Norwich, NY 13815

Project Name: Harrold Campus / HC - Sidney

Center  
Project / PO Number: 26-02305  
Received: 12/15/2025  
Reported: 01/14/2026

Analytical Testing Parameters

Client Sample ID: Kit 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-01

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1141 | JDF     |

Client Sample ID: Kit 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-02

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1143 | JDF     |

Client Sample ID: Kit 3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-03

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1145 | JDF     |

Client Sample ID: Kit 4  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-04

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS<br>Method: EPA 200.8, Rv. 5.4 (1994) | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|------------------------------------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Lead                                                       | 0.0029 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1146 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: [Kit 5](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [J5L0987-05](#)

Collected By: [Robert Durler](#)  
Collection Date: [12/05/2025 4:37](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1152 | JDF     |

Client Sample ID: [Kit 6](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [J5L0987-06](#)

Collected By: [Robert Durler](#)  
Collection Date: [12/05/2025 4:38](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0021 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1154 | JDF     |

Client Sample ID: [Kit 7](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [J5L0987-07](#)

Collected By: [Robert Durler](#)  
Collection Date: [12/05/2025 4:40](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1156 | JDF     |

Client Sample ID: [Bakery](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [J5L0987-08](#)

Collected By: [Robert Durler](#)  
Collection Date: [12/05/2025 4:41](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0016 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1157 | JDF     |

Client Sample ID: [Ice](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [J5L0987-09](#)

Collected By: [Robert Durler](#)  
Collection Date: [12/05/2025 4:42](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0012 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1203 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 106 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-10

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1205 | JDF     |

Client Sample ID: 106 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-11

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0017 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1207 | JDF     |

Client Sample ID: 1 STDF -1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-12

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0159 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1208 | JDF     |

Client Sample ID: 1 STDF-2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-13

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1111 | 01/08/26 1210 | JDF     |

Client Sample ID: 111-DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-14

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1337 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 112 - K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-15

Collected By: Robert Durler  
Collection Date: 12/05/2025 4:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0015 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1342 | JDF     |

Client Sample ID: 113 - 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-16

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0014 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1344 | JDF     |

Client Sample ID: 113 - 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-17

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0012 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1346 | JDF     |

Client Sample ID: 113 - 3  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-18

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0011 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1348 | JDF     |

Client Sample ID: 200  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-19

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1349 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 201  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-20

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1355 | JDF     |

Client Sample ID: 202  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-21

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1357 | JDF     |

Client Sample ID: 204  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-22

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1359 | JDF     |

Client Sample ID: 2nd DF 202  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-23

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1400 | JDF     |

Client Sample ID: 206  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-24

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0012 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1402 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 207  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-25

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0012 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1406 | JDF     |

Client Sample ID: 208 - K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-26

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1408 | JDF     |

Client Sample ID: 209  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-27

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0018 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1410 | JDF     |

Client Sample ID: 210  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-28

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:22

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0018 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1411 | JDF     |

Client Sample ID: 211  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-29

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1417 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 212  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-30

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0017 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1419 | JDF     |

Client Sample ID: 2nd DF 213  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-33

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1421 | JDF     |

Client Sample ID: Office - K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-34

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0011 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1422 | JDF     |

Client Sample ID: 217  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-35

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1326 | 01/08/26 1424 | JDF     |

Client Sample ID: 219 Lab  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-36

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0014 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1433 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 219 Exam  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-37

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0014 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1439 | JDF     |

Client Sample ID: 227 - 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-38

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0025 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1441 | JDF     |

Client Sample ID: 2nd DF 227.1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-39

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1443 | JDF     |

Client Sample ID: 224  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-40

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1444 | JDF     |

Client Sample ID: 2nd DF 231 - 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-41

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1446 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 2nd DF 231 - 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-42

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1452 | JDF     |

Client Sample ID: 233  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-43

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0021 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1454 | JDF     |

Client Sample ID: 234  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-44

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1455 | JDF     |

Client Sample ID: 303  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-45

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0030 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1457 | JDF     |

Client Sample ID: 3rd DF 303 -1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-46

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1459 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 3rd DF 303 - 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-47

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1503 | JDF     |

Client Sample ID: 304  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-48

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0031 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1505 | JDF     |

Client Sample ID: 305  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-49

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1506 | JDF     |

Client Sample ID: 306  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-50

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0026 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1508 | JDF     |

Client Sample ID: 3rd DF 306  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-51

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0015 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1514 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 3rd DF Cafe  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-52

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1516 | JDF     |

Client Sample ID: DF Gym - 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-53

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0015 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1517 | JDF     |

Client Sample ID: DF Gym - 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-54

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1519 | JDF     |

Client Sample ID: 3rd DF 312 - 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-55

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1327 | 01/08/26 1521 | JDF     |

Client Sample ID: 3rd DF 312 - 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-56

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1239 | DLO     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 314  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-57

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0018 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1244 | DLO     |

Client Sample ID: 316 - K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-58

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0015 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1246 | DLO     |

Client Sample ID: 317 - K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-59

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0012 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1248 | DLO     |

Client Sample ID: 317 - D  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-60

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0054 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1250 | DLO     |

Client Sample ID: 5th DF - 1  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-61

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1251 | DLO     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 5th DF - 2  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-62

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1257 | DLO     |

Client Sample ID: 502  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-63

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0064 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1259 | DLO     |

Client Sample ID: 505  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-64

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0014 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1301 | DLO     |

Client Sample ID: 504 - K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-65

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0099 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1302 | DLO     |

Client Sample ID: 506  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-66

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0090 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1304 | DLO     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: Autobody DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-67

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1308 | DLO     |

Client Sample ID: Autotech DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-68

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1310 | DLO     |

Client Sample ID: Bldg Trade DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-69

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1312 | DLO     |

Client Sample ID: Fleet DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-70

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0041 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1314 | DLO     |

Client Sample ID: Welding DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-71

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1319 | DLO     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: Conseq DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-72

Collected By: Robert Durler  
Collection Date: 12/05/2025 6:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1321 | DLO     |

Client Sample ID: Cons DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-73

Collected By: Robert Durler  
Collection Date: 12/05/2025 7:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0048 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1323 | DLO     |

Client Sample ID: HH DF  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-74

Collected By: Robert Durler  
Collection Date: 12/05/2025 7:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0045 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1325 | DLO     |

Client Sample ID: HH K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-75

Collected By: Robert Durler  
Collection Date: 12/05/2025 7:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0013 | 0.0050 AL | 0.0010 | mg/L  |      | 01/09/26 1127 | 01/09/26 1326 | DLO     |

Client Sample ID: O&M BR - 4  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-76

Collected By: Robert Durler  
Collection Date: 12/05/2025 7:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|--------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |        |           |        |       |      |               |               |         |
| Lead                              | 0.0019 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1707 | 01/08/26 1929 | JDF     |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0987

Client Sample ID: 400 - K  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-77

Collected By: Robert Durler  
Collection Date: 12/05/2025 7:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1707 | 01/08/26 1934 | JDF     |

Client Sample ID: 2nd DF 234  
Sample Matrix: Drinking Water  
Lab Sample ID: J5L0987-78

Collected By: Robert Durler  
Collection Date: 12/05/2025 5:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

| Metals Total by ICPMS             | Result  | Limit(s)  | RL     | Units | Note | Prepared      | Analyzed      | Analyst |
|-----------------------------------|---------|-----------|--------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) |         |           |        |       |      |               |               |         |
| Lead                              | <0.0010 | 0.0050 AL | 0.0010 | mg/L  |      | 01/08/26 1707 | 01/08/26 1936 | JDF     |

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level  
MCL: US EPA Maximum Contaminant Level  
mg/L: Milligrams per Liter  
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville  
11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division  
68-01385

Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.**

Reviewed and Approved By:

Shannon Weeks

Operations Manager

Reported: 01/14/2026 08:02

CHAIN OF CUSTODY RECORD

Number

Instructions on back

Lab Report Address

Client Name: **DCMO BOCES / HC**  
 Address: **270 Boces Drive**  
 City, State, Zip: **Sidney Center, NY 13839**  
 Contact: **Robert Durler**  
 Telephone No.: **607-865-2624**

Invoice Address

Client Name: **DCMO BOCES**  
 Address: **6678 County Road 32**  
 City, State, Zip: **Norwich, NY 13815**  
 Contact: **Robert Durler**  
 Telephone No.: **607-865-2624**

Turnaround Time

☒ Routine (5 to 7 business days)  
☐ RUSH\* (notify lab)

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **-0.8**  
 Therm ID **IR-1**  
 Holding Time

Send Report via:

☒ Mail ☐ Fax ☒ e-mail (address)

**durler@dcmoboces.com**

Send Invoice via:

☒ Mail ☐ Fax ☐ e-mail (address)

Project: **Harrold Campus / HC**

Location: **Sidney Center NY**

PO No.: **26-02305**

Compliance Monitoring? ☒ Yes ☐ No

☒ Agency/Program **DOH / NYSED**

Sampled by (PRINT): **Robert Durler**

Sampler Signature: **Robert D. Durler**

Sampler Phone No.: **607-865-2624**

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved


**RLF 12/15/25**

REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 1      | Kit-1            | 12/5           | 4:31AM         | 1                 | DW     |             | HNO3                  |
| 2      | Kit-2            | 12/5           | 4:34AM         | 1                 | DW     |             | HNO3                  |
| 3      | Kit-3            | 12/5           | 4:35AM         | 1                 | DW     |             | HNO3                  |
| 4      | Kit-4            | 12/5           | 4:36AM         | 1                 | DW     |             | HNO3                  |
| 5      | Kit-5            | 12/5           | 4:37AM         | 1                 | DW     |             | HNO3                  |
| 6      | Kit-6            | 12/5           | 4:38AM         | 1                 | DW     |             | HNO3                  |
| 7      | Kit-7            | 12/5           | 4:40AM         | 1                 | DW     |             | HNO3                  |
| 8      | Bakery           | 12/5           | 4:41AM         | 1                 | DW     |             | HNO3                  |
| 9      | Ice              | 12/5           | 4:42AM         | 1                 | DW     |             | HNO3                  |
| 10     | 106-1            | 12/5           | 4:48AM         | 1                 | DW     |             | HNO3                  |

\*

LEAD



Possible Hazard Identification

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition

☐ Dispose as appropriate ☐ Return ☐ Archive

Comments

**\* All First Draw**  
**Last use 12/4 2:30pm**

Relinquished By (signature)

**Robert D. Durler**

Date/Time

**12/5/25 10:14AM**

Received By (signature)

**Cassandra Decker**

Date/Time

**12/5/25 10:15**

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

**\* HNO3 ADDED TO SAMPLES - J547017 - RLF 12/09/25**

rev. 7/18/18

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

## Lab Report Address

Client Name: DCMO BOCES / HC

Address: 270 Bocess Drive

City, State, Zip: Sidney Center, NY 13839

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Harrold Campus / HC

Sampled by (PRINT): Robert Durler

## Invoice Address

Client Name: DCMO BOCES

Address: 6678 County Road 32

City, State, Zip: Norwich, NY 13815

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Location: Sidney Center NY

Sampler Signature: Robert D. Durler

## Turnaround Time

☒ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Compliance Monitoring? ☒ Yes ☐ No

Agency/Program: DOH / NYSED

Sampler Phone No.: 607-865-2624

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 11     | 106-2            | 12/5           | 4:49 AM        | 1                 | DW     |             | HNO3                  |
| 12     | 1 STDF-1         | 12/5           | 4:52 AM        | 1                 | DW     |             | HNO3                  |
| 13     | 1 STDF-2         | 12/5           | 4:54 AM        | 1                 | DW     |             | HNO3                  |
| 14     | 111-DF           | 12/5           | 4:56 AM        | 1                 | DW     |             | HNO3                  |
| 15     | 112-K            | 12/5           | 4:58 AM        | 1                 | DW     |             | HNO3                  |
| 16     | 113-1            | 12/5           | 5:00 AM        | 1                 | DW     |             | HNO3                  |
| 17     | 113-2            | 12/5           | 5:01 AM        | 1                 | DW     |             | HNO3                  |
| 18     | 113-3            | 12/5           | 5:02 AM        | 1                 | DW     |             | HNO3                  |
| 19     | 200              | 12/5           | 5:06 AM        | 1                 | DW     |             | HNO3                  |
| 20     | 201              | 12/5           | 5:08 AM        | 1                 | DW     |             | HNO3                  |



Possible Hazard Identification

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Comments

All First Draw  
Last use: 12/4 2:30 PM

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

## Lab Report Address

Client Name: DCMO BOCES / HC

Address: 270 Bocess Drive

City, State, Zip: Sidney Center, NY 13839

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Harrold Campus / HC

Sampled by (PRINT): Robert Durler

## Invoice Address

Client Name: DCMO BOCES

Address: 6678 County Road 32

City, State, Zip: Norwich, NY 13815

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Location: Sidney Center NY

Sampler Signature: Robert D. Durler

## Turnaround Time

☒ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Compliance Monitoring? ☒ Yes ☐ No

Agency/Program: DOH / NYSED


Sampler Phone No.: 607-865-2624

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 21     | 202              | 12/5           | 5:10AM         | 1                 | DW     |             | HNO3                  |
| 22     | 204              | 12/5           | 5:13AM         | 1                 | DW     |             | HNO3                  |
| 23     | 2ND DF 202       | 12/5           | 5:14AM         | 1                 | DW     |             | HNO3                  |
| 24     | 206              | 12/5           | 5:15AM         | 1                 | DW     |             | HNO3                  |
| 25     | 207              | 12/5           | 5:17AM         | 1                 | DW     |             | HNO3                  |
| 26     | 208-K            | 12/5           | 5:19AM         | 1                 | DW     |             | HNO3                  |
| 27     | 209              | 12/5           | 5:21AM         | 1                 | DW     |             | HNO3                  |
| 28     | 210              | 12/5           | 5:22AM         | 1                 | DW     |             | HNO3                  |
| 29     | 211              | 12/5           | 5:23AM         | 1                 | DW     |             | HNO3                  |
| 30     | 212              | 12/5           | 5:25AM         | 1                 | DW     |             | HNO3                  |



Possible Hazard Identification

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

Comments

All First Draw  
Last use: 12/4 2:30PM

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time



# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)  
Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

## Lab Report Address

Client Name: DCMO BOCES / HC

Address: 270 Bocas Drive

City, State, Zip: Sidney Center, NY 13839

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Harrold Campus / HC

Sampled by (PRINT): Robert Durler

## Invoice Address

Client Name: DCMO BOCES

Address: 6678 County Road 32

City, State, Zip: Norwich, NY 13815

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Location: Sidney Center NY

Sampler Signature: Robert D. Durler

## Turnaround Time

☒ Routine (5 to 7 business days)  
☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Compliance Monitoring? ☒ Yes ☐ No

Agency/Program: DOH / NYSED

Sampler Phone No.: 607-865-2624

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 41     | 2ND DF 231-1     | 12/5           | 5:44AM         | 1                 | DW     |             | HNO3                  |
| 42     | 2ND DF 231-2     | 12/5           | 5:45AM         | 1                 | DW     |             | HNO3                  |
| 43     | 233              | 12/5           | 5:47AM         | 1                 | DW     |             | HNO3                  |
| 44     | 234              | 12/5           | 5:49AM         | 1                 | DW     |             | HNO3                  |
| 45     | 303              | 12/5           | 5:56AM         | 1                 | DW     |             | HNO3                  |
| 46     | 3RD DF 303-1     | 12/5           | 5:58AM         | 1                 | DW     |             | HNO3                  |
| 47     | 3RD DF 303-2     | 12/5           | 5:59AM         | 1                 | DW     |             | HNO3                  |
| 48     | 304              | 12/5           | 6:00AM         | 1                 | DW     |             | HNO3                  |
| 49     | 305              | 12/5           | 6:02AM         | 1                 | DW     |             | HNO3                  |
| 50     | 306              | 12/5           | 6:03AM         | 1                 | DW     |             | HNO3                  |

DCMO Bocas  
PM: Shannon Weeks



Possible Hazard Identification

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Comments

\* First Draw

Last use: 12/4 2:30PM

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

CHAIN OF CUSTODY RECORD

Number

Instructions on back

Lab Report Address

Client Name: DCMO BOCES / HC

Address: 270 Boces Drive

City, State, Zip: Sidney Center, NY 13839

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Report via: ☒ Mail ☐ Fax ☒ e-mail (address)

Project: Harrold Campus / HC

Sampled by (PRINT): Robert Durler

Invoice Address

Client Name: DCMO BOCES

Address: 6678 County Road 32

City, State, Zip: Norwich, NY 13815

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Location: Sidney Center NY

Sampler Signature: Robert D. Durler

Turnaround Time

☒ Routine (5 to 7 business days)  
☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Compliance Monitoring? ☒ Yes ☐ No  
Agency/Program: DOH / NYSED

Sampler Phone No.: 607-865-2624

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 51     | 3RD DF 306       | 12/5           | 6:05AM         | 1                 | DW     |             | HNO3                  |
| 52     | 3RD DF CAFE      | 12/5           | 6:11AM         | 1                 | DW     |             | HNO3                  |
| 53     | DF GYM-1         | 12/5           | 6:14AM         | 1                 | DW     |             | HNO3                  |
| 54     | DF GYM-2         | 12/5           | 6:15AM         | 1                 | DW     |             | HNO3                  |
| 55     | 3RD DF 312-1     | 12/5           | 6:16AM         | 1                 | DW     |             | HNO3                  |
| 56     | 3RD DF 312-2     | 12/5           | 6:17AM         | 1                 | DW     |             | HNO3                  |
| 57     | 314              | 12/5           | 6:19AM         | 1                 | DW     |             | HNO3                  |
| 58     | 316-K            | 12/5           | 6:21AM         | 1                 | DW     |             | HNO3                  |
| 59     | 317-K            | 12/5           | 6:23AM         | 1                 | DW     |             | HNO3                  |
| 60     | 317-D            | 12/5           | 6:24AM         | 1                 | DW     |             | HNO3                  |



Possible Hazard Identification

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Comments

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

\* All First Draw  
Last use: 12/4 2:30PM

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

12/5/2025 10:14PM

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Turnaround Time

☒ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: DCMO BOCES / HC

Address: 270 Boces Drive

City, State, Zip: Sidney Center, NY 13839

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Harrold Campus / HC

Sampled by (PRINT): Robert Durler

Invoice Address

Client Name: DCMO BOCES

Address: 6678 County Road 32

City, State, Zip: Norwich, NY 13815

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address)

Location: Sidney Center NY

Sampler Signature: Robert D. Durler

PO No.: 26-023051

Compliance Monitoring? ☒ Yes ☐ No

Agency/Program: DCM / NYSED

Sampler Phone No.: 607-865-2624

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 61     | 5TH DF-1         | 12/5           | 6:31AM         | 1                 | DW     |             | HNO3                  |
| 62     | 5TH DF-2         | 12/5           | 6:32AM         | 1                 | DW     |             | HNO3                  |
| 63     | 502              | 12/5           | 6:34AM         | 1                 | DW     |             | HNO3                  |
| 64     | 505              | 12/5           | 6:36AM         | 1                 | DW     |             | HNO3                  |
| 65     | 504-K            | 12/5           | 6:41AM         | 1                 | DW     |             | HNO3                  |
| 66     | 506              | 12/5           | 6:43AM         | 1                 | DW     |             | HNO3                  |
| 67     | Autobody DF      | 12/5           | 6:46AM         | 1                 | DW     |             | HNO3                  |
| 68     | Autotech DF      | 12/5           | 6:47AM         | 1                 | DW     |             | HNO3                  |
| 69     | BLDG TRADE DF    | 12/5           | 6:49AM         | 1                 | DW     |             | HNO3                  |
| 70     | Fleet DF         | 12/5           | 6:52AM         | 1                 | DW     |             | HNO3                  |



Possible Hazard Identification

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Comments

All First Draw  
Last use: 12/4 2:30pm

Sample Disposition

☐ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

## CHAIN OF CUSTODY RECORD

Number

Instructions on back

## Lab Report Address

Client Name: DCMO BOCES / HC

Address: 270 Bocess Drive

City, State, Zip: Sidney Center, NY 13839

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Report via:

☒ Mail☐ Fax☒ e-mail (address)

## Invoice Address

Client Name: DCMO BOCES

Address: 6678 County Road 32

City, State, Zip: Norwich, NY 13815

Contact: Robert Durler

Telephone No.: 607-865-2624

Send Invoice via:

## Turnaround Time

☒ Routine (5 to 7 business days)☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/ACustody Seals Intact? ☐ Yes ☐ No ☐ N/A

Project: Harrold Campus / HC

Location: Sidney Center NY

PO No.:

26-023057

Compliance Monitoring? ☒ Yes ☐ No

Agency/Program DCM / NYSED

Sampled by (PRINT): Robert Durler

Sampler Signature:

Robert D. Durler

Sampler Phone No.:

607-865-2624

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

| Lab ID | Client Sample ID | Date Collected | Time Collected | No. of Containers | Matrix | Grab / Comp | Preservative Types ** |
|--------|------------------|----------------|----------------|-------------------|--------|-------------|-----------------------|
| 71     | Welding DF       | 12/5           | 6:55AM         | 1                 | DW     |             | HNO3                  |
| 72     | CONSEQ DF        | 12/5           | 6:59AM         | 1                 | DW     |             | HNO3                  |
| 73     | CONS DF          | 12/5           | 7:06AM         | 1                 | DW     |             | HNO3                  |
| 74     | HH DF            | 12/5           | 7:08AM         | 1                 | DW     |             | HNO3                  |
| 75     | HH-K             | 12/5           | 7:09AM         | 1                 | DW     |             | HNO3                  |
| 76     | OEM BR-4         | 12/5           | 7:16AM         | 1                 | DW     |             | HNO3                  |
| 77     | 400-K            | 12/5           | 7:17AM         | 1                 | DW     |             | HNO3                  |
| 78     | 2ND DF 234       | 12/5           | 5:52PM         | 1                 | DW     |             | HNO3                  |
|        |                  |                |                | 1                 | DW     |             | HNO3                  |
|        |                  |                |                | 1                 | DW     |             | HNO3                  |

DCMO Bocess  
PM: Shannon Weeks

Possible Hazard Identification

☒ Hazardous☐ Non-Hazardous☐ Radioactive

Comments

\* All First Draw

Last use: 12/4 2:30PM

Sample Disposition

☒ Dispose as appropriate☐ Return☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time