

November 18, 2025

John Strickland
Cleveland Hill UFSD
105 Mapleview Road
Cheektowaga, New York 14225

Re: Lead Testing in School Drinking Water

Dear Mr. Strickland

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Cleveland Hill UFSD including:

- Cleveland Hill Elementary School, District Office, Cafeteria, and Athletics Rooms
 - 105 Mapleview Road, Cheektowaga, New York

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on October 21, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 0 sources of potable water in the Cleveland Hill Elementary School, District Office, Cafeteria, and Athletics Rooms have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion.

Thank you for the opportunity to be of service to Cleveland Hill UFSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Cleveland Hill UFSD

Prepared by:



Conditions as of October 21, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Cleveland Hill UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Cleveland Hill Elementary School, District Office, Cafeteria, and Athletics Rooms
 - 105 Maplevue Road, Cheektowaga, New York

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Cleveland Hill Elementary School, District Office, Cafeteria, and Athletics Rooms. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at the Cleveland Hill Elementary School, District Office, Cafeteria, and Athletics Rooms:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Cleveland Hill ES, DO, Cafe, and Athletics Rooms	10/21/2025	51	51	0

**NYS Action Level is 5 parts per billion*

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

All the locations sampled were analyzed at less than the NYS Action Level of 5 ppb, therefore no further response action is required.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



November 11, 2025

Service Request No:R2513911

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Cleveland Hill UFSD Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 24, 2025
For your reference, these analyses have been assigned our service request number **R2513911**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary
Sample Matrix: Drinking Water

Service Request: R2513911
Date Received: 10/24/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/24/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro

Date 11/11/2025



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request:R2513911

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513911-001	CHCS 5	10/21/2025	
R2513911-002	CHCS 6	10/21/2025	
R2513911-003	CHCS 7	10/21/2025	
R2513911-004	CHCS 29	10/21/2025	
R2513911-005	CHCS 30	10/21/2025	
R2513911-006	CHCS 40	10/21/2025	
R2513911-007	CHCS 41	10/21/2025	
R2513911-008	CHCS 50	10/21/2025	
R2513911-009	CHCS 51	10/21/2025	
R2513911-012	CHCS 63	10/21/2025	
R2513911-013	CHCS 64	10/21/2025	
R2513911-014	CHCS 65	10/21/2025	
R2513911-015	CHCS 89	10/21/2025	
R2513911-016	CHCS 90	10/21/2025	
R2513911-017	CHCS 91	10/21/2025	
R2513911-018	CHCS 108	10/21/2025	
R2513911-019	CHCS 109	10/21/2025	
R2513911-020	CHCS 111	10/21/2025	
R2513911-021	CHCS 112	10/21/2025	
R2513911-022	CHCS 120	10/21/2025	
R2513911-023	CHCS 121	10/21/2025	
R2513911-024	CHCS 122	10/21/2025	
R2513911-025	CHCS 134	10/21/2025	
R2513911-026	CHCS 135	10/21/2025	
R2513911-027	CHCS 137	10/21/2025	
R2513911-028	CHCS 138	10/21/2025	
R2513911-029	CHCS 149	10/21/2025	
R2513911-030	CHCS 150	10/21/2025	
R2513911-031	CHCS 202	10/21/2025	
R2513911-032	CHCS 204	10/21/2025	
R2513911-033	CHCS 205	10/21/2025	
R2513911-034	CHCS 206	10/21/2025	
R2513911-035	CHCS 213	10/21/2025	
R2513911-036	CHCS 214	10/21/2025	



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-145.1

Client: Cleveland Hill UFSD

Contact: John Strickland

Building: Cleveland Hill Elementary

Location: 105 Maplevue Road, Cheektowaga, NY 14225-1599

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
CHCS 5	District Hall	Fountain	5:37
CHCS 6	District Hall	Bottle Filler	5:38
CHCS 7	District Hall	Fountain	5:39
CHCS 29	Hall by Rm. 104	Bottle Filler	5:23
CHCS 30	Hall by Rm. 104	Fountain	5:24
CHCS 40	Hall across from Nurse	Bottle Filler	5:25
CHCS 41	Hall across from Nurse	Fountain	5:26
CHCS 50	Hall Across from Rm. 142A	Bottle Filler	5:27
CHCS 51	Hall Across from Rm. 142A	Fountain	5:28
CHCS 53	Hall Across from Rm. 142A	Bottle Filler	5:29
CHCS 54	Hall Across from Rm. 142A	Fountain	5:30
CHCS 63	ES Nurse Treatment Room 140B	Sink	5:31
CHCS 64	HS Nurse Treatment Room 139A	Ice Machine	5:32
CHCS 65	HS Nurse Treatment Room 139A	Sink	5:33
CHCS 89	Across Hall from ES Aud	Fountain	5:34
CHCS 90	Across Hall from ES Aud	Bottle Filler	5:35
CHCS 91	Across Hall from ES Aud	Fountain	5:36
CHCS 108	Across hall from 208	Bottle Filler	5:45

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Stohl Env: Jared Rider Date: 10/21/2025

Relinquished By: _____ Print Name Stohl Env: Connor Crilly Date: 10/22/2025

Received (Name / Lab): gmm mmm ALS Date: 10/24/25 Time: 8:14

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

Page 1 of 3

R2513911

Stohl Environmental
Cleveland Hill UFSD Elementary

5





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-145.1

Client: Cleveland Hill UFSD

Contact: John Strickland

Building: Cleveland Hill Elementary

Location: 105 Maplevue Road, Cheektowaga, NY 14225-1599

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
CHCS 109	Across hall from 208	Fountain	5:46
CHCS 111	Across hall from 208	Bottle Filler	5:47
CHCS 112	Across hall from 208	Fountain	5:48
CHCS 120	Across Hall from 207	Fountain	5:49
CHCS 121	Across Hall from 207	Bottle Filler	5:50
CHCS 122	Across Hall from 207	Fountain	5:51
CHCS 134	Across hall from 240A	Bottle Filler	5:52
CHCS 135	Across hall from 240A	Fountain	5:53
CHCS 137	Across hall from 240A	Bottle Filler	5:54
CHCS 138	Across hall from 240A	Fountain	5:55
CHCS 149	Across Hall From 237	Bottle Filler	5:56
CHCS 150	Across Hall From 237	Fountain	5:57
CHCS 202	Athletic Training Room	Ice Machine	5:37
CHCS 204	Athletic Hall Across from B. LckRm	Fountain	5:38
CHCS 205	Athletic Hall Across from B. LckRm	Bottle Filler	5:39
CHCS 206	Athletic Hall Across from B. LckRm	Fountain	5:40
CHCS 213	Main Street Left of Trophy Case	Bottle Filler	5:41
CHCS 214	Main Street Left of Trophy Case	Fountain	5:42

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Mscinta@stohlenvironmental.com

Sampled By: <u>Jared Rider</u>	Print Name	Stohl Env: <u>Jared Rider</u>	Date: <u>10/21/2025</u>
Relinquished By: _____	Print Name	Stohl Env: <u>Connor Crilly</u>	Date: <u>10/22/2025</u>
Received (Name / Lab): <u>Mmm Rmm ALS</u>	Date: <u>10/24/25</u>	Time: <u>8:14</u>	
Sample Login (Name / Lab): _____	Date: _____	Time: _____	
Analysis (Name / Lab): _____	Date: _____	Time: _____	
QA/QC Review (Name / Lab): _____	Date: _____	Time: _____	
Archived / Released: _____	QA/QC InterLAB Use: _____	Date: _____	Time: _____



Cooler Receipt and Preservation

R2513911

5

Stohl Environmental
Cleveland Hill UFSD ElementaryProject/Client Stohl

Folder Number

Cooler received on 10/24/25by: RMCOURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings

Date: 10/24/25 Time: 8:23ID: IR#12 (IR#11)

From: Temp Blank

Sample Bottle

Temp (°C)	<u>10.4</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: NO ice Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by:

All samples held in storage location: SMO by RM on 10/24 at 8:30

5035 samples placed in storage location: by on at within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/27/25 Time: 1640 by: CL9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? (YES) NO10. Did all bottle labels and tags agree with custody papers? (YES) (NO)11. Were correct containers used for the tests indicated? (YES) NO12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)13. Were dissolved metals filtered in the field? YES NO (N/A)14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO ₃					<u>All</u>	<u>4ml</u>	<u>244544</u>	<u>✓</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers:

08/125-2ADD

Explain all Discrepancies/ Other Comments:

10) Did not receive CHCS 53, + CHCS 54

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CL

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513911

Sample Name: CHCS 5
Lab Code: R2513911-001
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 6
Lab Code: R2513911-002
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 7
Lab Code: R2513911-003
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 29
Lab Code: R2513911-004
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 30
Lab Code: R2513911-005
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513911

Sample Name: CHCS 40
Lab Code: R2513911-006
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 41
Lab Code: R2513911-007
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 50
Lab Code: R2513911-008
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 51
Lab Code: R2513911-009
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 63
Lab Code: R2513911-012
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513911

Sample Name: CHCS 64
Lab Code: R2513911-013
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 65
Lab Code: R2513911-014
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 89
Lab Code: R2513911-015
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 90
Lab Code: R2513911-016
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 91
Lab Code: R2513911-017
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513911

Sample Name: CHCS 108
Lab Code: R2513911-018
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 109
Lab Code: R2513911-019
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 111
Lab Code: R2513911-020
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 112
Lab Code: R2513911-021
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 120
Lab Code: R2513911-022
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513911

Sample Name: CHCS 121
Lab Code: R2513911-023
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 122
Lab Code: R2513911-024
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 134
Lab Code: R2513911-025
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 135
Lab Code: R2513911-026
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 137
Lab Code: R2513911-027
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513911

Sample Name: CHCS 138
Lab Code: R2513911-028
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 149
Lab Code: R2513911-029
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 150
Lab Code: R2513911-030
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 202
Lab Code: R2513911-031
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 204
Lab Code: R2513911-032
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513911

Sample Name: CHCS 205
Lab Code: R2513911-033
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 206
Lab Code: R2513911-034
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 213
Lab Code: R2513911-035
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 214
Lab Code: R2513911-036
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 5
Lab Code: R2513911-001

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 6
Lab Code: R2513911-002

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 7
Lab Code: R2513911-003

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 29
Lab Code: R2513911-004

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 30
Lab Code: R2513911-005

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 40
Lab Code: R2513911-006

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 41
Lab Code: R2513911-007

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 50
Lab Code: R2513911-008

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 51
Lab Code: R2513911-009

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 63
Lab Code: R2513911-012

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 64
Lab Code: R2513911-013

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 65
Lab Code: R2513911-014

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 89
Lab Code: R2513911-015

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 90
Lab Code: R2513911-016

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 91
Lab Code: R2513911-017

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 108
Lab Code: R2513911-018

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 109
Lab Code: R2513911-019

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 111
Lab Code: R2513911-020

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 112
Lab Code: R2513911-021

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 120
Lab Code: R2513911-022

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 121
Lab Code: R2513911-023

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 122
Lab Code: R2513911-024

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 134
Lab Code: R2513911-025

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 135
Lab Code: R2513911-026

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 137
Lab Code: R2513911-027

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 138
Lab Code: R2513911-028

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 149
Lab Code: R2513911-029

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 150
Lab Code: R2513911-030

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 202
Lab Code: R2513911-031

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 204
Lab Code: R2513911-032

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 205
Lab Code: R2513911-033

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 206
Lab Code: R2513911-034

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 213
Lab Code: R2513911-035

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 214
Lab Code: R2513911-036

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:12	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513911-MB1

Service Request: R2513911
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 12:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513911-MB2

Service Request: R2513911
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 13:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513911-MB3

Service Request: R2513911
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:09	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: CHCS 89
Lab Code: R2513911-015
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.5	20.0	103	20.4	20.0	102	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: CHCS 90
Lab Code: R2513911-016
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.3	20.0	102	20.2	20.0	101	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: CHCS 213
Lab Code: R2513911-035
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.8	20.0	99	19.6	20.0	98	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513911
Date Collected: 10/21/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: CHCS 214
Lab Code: R2513911-036
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.8	20.0	99	19.6	20.0	98	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513911
Date Analyzed: 11/06/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513911-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	105	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513911

Date Analyzed: 11/06/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513911-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	103	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513911

Date Analyzed: 11/06/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513911-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.6	20.0	98	85-115



November 11, 2025

Service Request No:R2513912

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Cleveland Hill UFSD Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 24, 2025
For your reference, these analyses have been assigned our service request number **R2513912**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary
Sample Matrix: Drinking Water

Service Request: R2513912
Date Received: 10/24/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Seventeen drinking water samples were received for analysis at ALS Environmental on 10/24/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read "Meghan Pedicini".

Date

11/11/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: CHCS 243			Lab ID: R2513912-011			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request:R2513912

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513912-001	CHCS 215	10/21/2025	
R2513912-002	CHCS 216	10/21/2025	
R2513912-003	CHCS 227	10/21/2025	
R2513912-004	CHCS 228	10/21/2025	
R2513912-005	CHCS 229	10/21/2025	
R2513912-006	CHCS 230	10/21/2025	
R2513912-007	CHCS 231	10/21/2025	
R2513912-008	CHCS 233	10/21/2025	
R2513912-009	CHCS 235	10/21/2025	
R2513912-010	CHCS 236	10/21/2025	
R2513912-011	CHCS 243	10/21/2025	
R2513912-012	CHCS 245	10/21/2025	
R2513912-013	CHCS 246	10/21/2025	
R2513912-014	CHCS 247	10/21/2025	
R2513912-015	CHCS 248	10/21/2025	
R2513912-016	CHCS 253	10/21/2025	
R2513912-017	CHCS 254	10/21/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-145.1

Client: Cleveland Hill UFSD

Contact: John Strickland

Building: Cleveland Hill Elementary

Location: 105 Maplevue Road, Cheektowaga, NY 14225-1599

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
CHCS 215	Main Street Right of Trophy Case	Bottle Filler	5:43
CHCS 216	Main Street Right of Trophy Case	Fountain	5:44
CHCS 227	Kitchen	Combi Oven	5:10
CHCS 228	Kitchen	Combi Oven	5:11
CHCS 229	Kitchen	Potfiller	5:12
CHCS 230	Kitchen	Sink	5:13
CHCS 231	Kitchen	Sink	5:14
CHCS 233	Kitchen (Island Sink)	Island sink	5:15
CHCS 235	HS Serving Line	Sink	5:16
CHCS 236	HS Serving Line	Sink	5:17
CHCS 243	ES Serving Line	Sink	5:18
CHCS 245	ES Serving Line	Sink	5:19
CHCS 246	Near ES Serving Line Entrance	Fountain	5:20
CHCS 247	Near ES Serving Line Entrance	Bottle Filler	5:21
CHCS 248	Near ES Serving Line Entrance	Fountain	5:22

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 10/21/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 10/22/2025

Received (Name / Lab): Connor Crilly ALS Date: 10/24/25 Time: 8:14


Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____


Page 3 of 3





R2513912

5

Stohl Environmental
Cleveland Hill UFSD Elementary

Cooler Receipt and Preservation

Project/Client Stohl Folder Number _____Cooler received on 10/24/25 by: RMCOURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 10/24/25 Time: 8:23 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.4</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____All samples held in storage location: SMO by RM on 10/24 at 8:30
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y NCooler Breakdown/Preservation Check**: Date: 10/27 Time: 2200 by: AG

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
13. Were dissolved metals filtered in the field? YES NO N/A
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		<u>X</u>	<u>NO LOG INFO</u>		<u>ALL</u>	<u>4/mL</u>		<u>5.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513912

Sample Name: CHCS 215
Lab Code: R2513912-001
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 216
Lab Code: R2513912-002
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 227
Lab Code: R2513912-003
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 228
Lab Code: R2513912-004
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 229
Lab Code: R2513912-005
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513912

Sample Name: CHCS 230
Lab Code: R2513912-006
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 231
Lab Code: R2513912-007
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 233
Lab Code: R2513912-008
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 235
Lab Code: R2513912-009
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 236
Lab Code: R2513912-010
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513912

Sample Name: CHCS 243
Lab Code: R2513912-011
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 245
Lab Code: R2513912-012
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 246
Lab Code: R2513912-013
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 247
Lab Code: R2513912-014
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 248
Lab Code: R2513912-015
Sample Matrix: Drinking Water

Date Collected: 10/21/25**Date Received:** 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1

Service Request: R2513912

Sample Name: CHCS 253
Lab Code: R2513912-016
Sample Matrix: Drinking Water

Date Collected: 10/21/25
Date Received: 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: CHCS 254
Lab Code: R2513912-017
Sample Matrix: Drinking Water

Date Collected: 10/21/25
Date Received: 10/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 215
Lab Code: R2513912-001

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 216
Lab Code: R2513912-002

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 227
Lab Code: R2513912-003

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 228
Lab Code: R2513912-004

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 229
Lab Code: R2513912-005

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 230
Lab Code: R2513912-006

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 231
Lab Code: R2513912-007

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 233
Lab Code: R2513912-008

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 235
Lab Code: R2513912-009

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 236
Lab Code: R2513912-010

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 243
Lab Code: R2513912-011

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.4	ug/L	1.0	1	11/06/25 14:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 245
Lab Code: R2513912-012

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 246
Lab Code: R2513912-013

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 247
Lab Code: R2513912-014

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 248
Lab Code: R2513912-015

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 253
Lab Code: R2513912-016

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: CHCS 254
Lab Code: R2513912-017

Service Request: R2513912
Date Collected: 10/21/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:47	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513912-MB

Service Request: R2513912
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 14:09	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Cleveland Hill UFSD Elementary/2023L-145.1
Sample Matrix: Drinking Water

Service Request: R2513912
Date Analyzed: 11/06/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513912-LCS

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.6	20.0	98	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-6570 or by email to elap@health.ny.gov.

Page 1 of 5

