ADDENDUM NO. 2

April 10, 2026

This Addendum No. 2 is hereby made a part of the specifications and drawings and shall become a part of the Contract Documents. Receipt of this Addendum shall be acknowledged on Page 1 of the Contractor's Bid Form.

Item #1: Project Questions

1. CP-01 is shown to need rack panel but appears to be wall-mounted at stage right proscenium
   Correct, this is a typo. No rack panel required.

2. AMP-03 is mentioned on the oneline but there is no spec'd AMP-03 or one shown on the oneline.
   Assuming this is referring to the source for the BOH speakers on the schematic*. That is a typo/remnant, it is supposed to say 'AMP-02.'



