

1254 S. Florida Avenue, Rockledge, Fl 32955

EXIT LIGHT TEST LOG:

Testing for emergency lighting systems, including exit signs, shall be tested for proper operation for a minimum of 30 seconds every month. An annual test shall be conducted for one hour. Equipment shall function properly for the duration of the test. Submit a work order request for all broken lights.

Person Inspecting Units	Month / Year	Are all exit signs illuminated?	Are the battery back-ups for the exit signs operating properly?	Do all emergency lights illuminate?	Do any units need to be repaired?