North Andrew School District R-VI

Josh Barker
9120 Hwy 48, Rosendale, Missouri 64483
Telephone: 816-567-2965; Fax: 816-567-2096
jbarker@northandrew.org

Chris Russo
Middle/High School Principal
Telephone: 816-567-2525
crusso@northandrew.org

Craig Walker
Elementary Principal
Telephone: 816-567-2527
cwalker@northandrew.org

North Andrew R-VI School District
District Water Testing Plan

Summary of Summer 2024 Water Testing Plan Update

Good news:

- Two out of three water supplies that previously exceeded lead limits have been addressed.
  - Unused classroom sink exceeding limit is not being used and will be addressed before use resumes.
  - Two outside hydrants with high lead levels were replaced in July 2024.

Test results from replacements:

- One hydrant (by concession stand) is now well below the lead limit.
- The other hydrant (by football field) is still above the limit but significantly lower than before.

Next steps:

- The district is working with a plumber and state health department to determine how to address the remaining hydrant exceeding the lead limit.

Contact:

- Josh Barker - 816-567-2965 or jbarker@northandrew.org

Additional notes:

- The original testing was conducted in November/December 2023.
- The allowable lead limit is less than 5.0 parts per billion (ppb).